



NEW MANGALORE PORT AUTHORITY
MECHANICAL ENGINEERING DEPARTMENT

ADDENDUM – 1

No. EE(M)II/2022-23/SS316 Foam Line

Date: 19/01/2023

Sub: Replacement of existing SS 316 Foam Line at Berth No.12 - Reg.

Ref: NIT No. CME-07/2022-23 dated 18/01/2023

New Mangalore Port Authority by way of this **Addendum – 1** is adding the clause No.15 to the scope of the work (Section - 5) for the subject tender which is as follows:

Sl. No	Additional Clause
1.	After completion of laying of the foam line, the entire line to be Hydro tested for 24 Kg/ cm ² for one hour and leakage found during the hydro test to be rectified immediately.

Note: The Addendum so issued shall form part of the Contract and shall be binding upon the Bidders. The Bidder shall acknowledge receipt of such Addenda/Corrigenda and submit the same along with his Tender duly signed and sealed in all pages.

(Sd/-)

Executive Engineer (Mech)- II
New Mangalore Port Authority