



नव मंगलूर पत्तन प्राधिकरण
NEW MANGALORE PORT AUTHORITY
यांत्रिक अभियंता विभाग
Mechanical Engineering Department
इलेक्ट्रिकल इंजिनियरिंग डिविजन, पणंबूर, मंगलूर
Electrical Engineering Division
Panambur, Mangalore – 575010

E-mail: ele-section@nmpt.gov.in
GSTIN: 29AAALN0057A2ZG

Phone: 0824 2887750/740/738
Fax: 0824 2408200/2408300

No. 8/3/2023/Ele. Dvn/EQ/01/02

Date: 13.01.2023

CORRIGENDUM NO. 1

Sub:- RFQ for the “Laying of LT UG cable and making straight through cable joint for High Mast Towers installed at Railway Marshalling Yard” – Corrigendum No. 1 – Reg.

Ref:-i) RFQ No: 8/3/2023/Ele. Dvn/EQ/01/02, dtd 12.01.2023.

With reference to the above RFQ, the following corrigendum has been issued.

Sl. No	Heading	Clause No & Page No.	Existing	Read as
1	Description of Work	BOQ Sl. No. 2	Supplying and laying of double walled corrugated HDPE Pipe including all necessary connecting Sockets/ couplings/ tees/ bends/end caps of same materials in existing trench as per IS 14930 part-II suitable for drawing underground cables.	Supplying and laying of 90mm OD/76mm ID double walled corrugated HDPE Pipe including all necessary connecting Sockets/ couplings/ tees/ bends/end caps of same materials in existing trench as per IS 14930 part-II suitable for drawing underground cables.

All other terms and conditions mentioned in the RFQ remain unaltered.

Sd/-
Executive Engineer (Ele)
NMPA, Panambur