


**NEW MANGALORE PORT AUTHORITY**  
**MARINE DEPARTMENT**

Phone: 0824 – 2887265 Fax: 0824-2407419 Email: me-section@nmpt.gov.in		PANAMBUR, MANGALORE – 575 010. Karnataka
---	---	--

**No. NMPA/ME/Iswari/2023/11**

**Date: 08-06-2023**

To:

The Prospective Bidders.

Sir,

Sub: Hydraulic pressure testing of Portable Fire Extinguishers(by D.G Shipping approved firms) on tug Iswari – Quotations requested. - Reg.

---

Kindly quote your lowest competitive rates for Hydraulic pressure testing of Portable Fire Extinguishers (by D.G Shipping approved firms) on tug Iswari.


Sl.No	Type of Ext	Capacity	Make	Qty (nos)	Amount, Rs
1	Water CO2 F/Ext	09 Ltrs	Pavlo	02	
2	AFFF F/Ext	09 Ltrs	Pavlo	04	
3	DCP F/Ext	05 Kg	-	02	
4	DCP F/Ext	06Kg	Pavlo	01	
5	AFFF(TR) F/Ext	50 Ltrs	Supremex	01	
Sub total					
Transportation charges to & from NMPA Mangalore for the above works					
Applicable GST					
Total					

### Terms and Conditions:

1. The Hydraulic pressure testing of empty containers has to be carried out at New Mangalore Port premises in presence of the Engineer, test certificate has to be handed over, containers to be filled up with the respective fresh charges, CO<sub>2</sub> cartridges to be weighed and weighment certificate to be submitted.
2. Any damage to the items or port properties shall be at contractor's account.
3. The time allotted for completion of the work is 05 working days on receipt of work order. The required tools and plant, labour, etc. should be arranged by the contractor.
4. Transportation charges if any are to be indicated separately, and requisite insurance coverage for the transit to be obtained.
5. Income tax would be deducted from the bill at the prevailing rates.

The quotation in complete shape in a sealed cover super-scribed as **“Quotation for Hydraulic pressure testing of Portable Fire Extinguisher containers on tug Iswari”** should reach the undersigned on or before **14.06.2023** by 14:45 hrs and will be opened on same day at 15:00 hrs.

Yours Sincerely



Sr. Dy. Marine Engineer

SHM/FFA/2305A

FFA06/00/01.08.02021

19.01.2022

## CERTIFICATE OF SERVICING

Ships Name TUG ISWARI

Date of inspection 19/01/2022

Owners Name NEW MANGALORE PORT TRUST

Flag India At Mangalore  
Page 1 of 2

This is to certify that the following works have been carried out by us as per the guidelines and the details are given below

Sl. No.	Type of Ext.	Capacity	Make	Qty	LPT	Work Done	Remarks
1	Water CO2 F/Ext	09 Ltrs	Pavlo	02	09/2019	A,B,C	Ext having Sl No 11363, 0666 found OK
2	AFFF F/Ext	09 Ltrs	Pavlo	04	09/2019	A,B,C	Ext having Sl No 659, 661, 658, 0869 found OK
3	DCP F/Ext.	05 Kg	-	02	09/2019	A,B	Ext having Sl No 286, 2522 found OK.
4	DCP F/Ext.	06 Kg	Pavlo	01	09/2019	A,B,G	Ext having Sl No 0835 found OK.
5	AFFF (TR) F/Ext	50 Ltrs	Supremex	01	09/2019	A,B,C	Ext having Sl No 508 found OK

\*Next pressure test due: 09/2022

**\*60 Gms CO2 Cartridge Weighment Details: 09 Ltr. Water Co2 Fire Extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight(in Gms)	Tare Weight (in Gms)	Actual Gas Weight(in Gms)	LPT	Remarks
1	1363	460	390	70	2020	OK

**\*90 Gms CO2 Cartridge Weighment Details: 09 Ltr. Water Co2 Fire Extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight(in Gms)	Tare Weight (in Gms)	Actual Gas Weight(in Gms)	LPT	Remarks
1	0666	625	529	96	2016	OK

**\*60 Gms CO2 Cartridge Weighment Details: 09 Ltr. AFFF Fire Extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight(in Gms)	Tare Weight (in Gms)	Actual Gas Weight(in Gms)	LPT	Remarks
1	659	470	400	70	2020	OK
2	661	454	384	70	2020	OK
3	658	410	340	70	2020	OK

Signature of Service Engineer



Competent Person

*(Handwritten Signature)*



safe seas, safe shores

SHM SHIPCARE  
Koch Branch

**\*90 Gms CO2 Cartridge Weighment Details: 09 Ltr. AFFF Fire Extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight(in Gms)	Tare Weight (in Gms)	Actual Gas Weight(in Gms)	LPT	Remarks
1	0869	710	617	93	2015	OK

**\*120 Gms CO2 Cartridge Weighment Details: 05 Kg. DCP Fire Extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight(in Gms)	Tare Weight (in Gms)	Actual Gas Weight(in Gms)	LPT	Remarks
1	286	660	530	130	2020	OK
2	2522	685	555	130	2020	OK

**\*120 Gms CO2 Cartridge Weighment Details: 06 Kg. DCP Fire Extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight(in Gms)	Tare Weight (in Gms)	Actual Gas Weight(in Gms)	LPT	Remarks
1	0835	854	724	130	2019	OK

**\*300 Gms CO2 Cartridge Weighment Details: 50 Ltrs. AFFF (TR) Fire extinguisher:**

Sl. No.	Extinguisher No.	Actual Gross Weight (in Gms)	Tare Weight (in Gms)	Actual Gas Weight (in Gms)	LPT	Remarks
1	508	1530	1220	310	2020	OK

\*The above fire extinguisher Co2 cartridge weighment carried out by using NABL calibrated 5 Kg. Weighing balance SI No. 181248 valid till 11 02 2022 (Copy of calibration certificate attached )

\*01 No. 05 Kg DCP fire extinguisher SI No: 286 discharged random and the retention of content checked and found satisfactory:

**DESCRIPTION OF WORKING CODE**

A	INSPECTION	E	WEIGHMENT
B	SERVICING	F	REPAIR
C	REFILLING	G	CO2 CARTRIDGE REPLACED
D	H.P. TESTING		

Signature of Service Engineer



Competent Person