



नव मंगलूरु पत्तन प्राधिकरण **NEW MANGALORE PORT AUTHORITY**

इलेक्ट्रिकल इंजिनियरिंग डिविजन / Electrical Engineering Division
पणंबूर मंगलूर / Panambur, Mangalore – 575 010.

Phone: 0824 – 2887746/2887739
E-Mail: ele-section@nmpt.gov.in

No.17/Panel Shift/EE(E)II/2024

Date:14.03.2024

To,
Website

Sir,

Sub: NMPA - EE(E)II – Shifting & fixing of LT Control Panels from Container Yard Transformer Centre to KK Gate Transformer Centre - Budgetary offer requested – Reg.

Budgetary offer for “Shifting & fixing of LT Control Panels from Container Yard Transformer Centre to KK Gate Transformer Centre” are invited as detailed in the Schedule and in accordance with the Terms and Conditions of Contract as detailed below, to be sent by **E-mail on or before 20.03.2024**.

SNo	Item Description	Qty	Rate/ Unit (Rs)	Total amount (Rs)
1	Increasing the height of existing feeder pillar foundation by 2 feet from ground level using stones providing new base plate and retermination of following cables 1. 3.5 C x 240 Sq.mm - 1No 2. 3.5 C x 95 Sq.mm - 2 Nos 3. 3.5 C x 16 Sq.mm - 2 nos	1 No		
2	Removing the SS LT panel from container yard site, Repairing the SS doors, hinges, locks. Transportation to KK gate yard structure (around 4km), Fixing it to existing foundation (Repairing foundation if required) and making the termination of existing cables (400 sq mm-2 Nos, 95 sq mm-1No, 25 to 50 Sq mm-6 Nos) (Work includes removing the old panel at KK Gate	1 Job		

	structure and transporting it to sub divisional premises (around 3.5 KM)			
	Total amount (Rs.)			
	Applicable GST in (%)			

Terms & Conditions of the Contract:

1. Time allowed for completion of subject work is 30 (thirty) days from the date of issue of work order.
2. The rate quoted shall be firm and applicable GST shall be mentioned separately.
3. The tenderer should have valid Electrical Contract License & copy of GST registration certificate.
4. Income Tax at the applicable rates will be recovered from the gross amount of the firm's bill as per the relevant provisions of the Acts.
5. The Rates quoted should be valid for **90 days**.
6. No Men, Materials, Testing Equipments, Food & Accommodation, Transport etc. required for the work will be supplied Departmentally and Contractor have to make their own arrangement.

-Sd/-

Executive Engineer(Ele)II
NMPA Panambur, Mangaluru