



NEW MANGALORE PORT AUTHORITY

Mechanical Engineering Department

Panambur, Mangalore - 575 010

Phone: 0824 - 2887730 / 701

No: 20/114/2022-23/EE(M)III-TS(OTM)

Dated 09.12.2022

To,

The Intended Tenderers

Sir,

Sub: NMPA - "Replacement of existing SS 316 Foam line at Berth No.12"
- Budgetary Quotation - Corrigendum issued - Reg.

Ref: NMPA's Budgetary enquiry letter No. 20/114/2022-23/EE(M)III-TS
(OTM) dated 06.12.2022.

The following Corrigendum is issued to the Budgetary Enquiry letter dated 06/12/2022 (Ref.) invited for the subject work.

- 1) The Schedule and wall thickness of 100 NB SS Pipe & fittings of AISI 316 (ASTM 312 GR. 316 TP) indicated at Sl. No.2 of BoQ in Enquiry letter (Ref.) to be considered as SCH 40 S and 6.02 mm wall thickness respectively,
- 2) The Schedule and wall thickness of 65 NB SS Pipe & fittings of AISI 316 (ASTM 312 GR. 316 TP) indicated at Sl. No.2 of BoQ in Enquiry letter (Ref.) to be considered as SCH 40 S and 5.16 mm wall thickness respectively,
- 3) Supply & laying of 65 NB SS 316 Flange indicated at Sl. No.2(vii) of BoQ in Enquiry letter (Ref.) to be read as Supply & laying of 65 NB SS 316 Flange as per ANSI B 16.5, Class 150# Raised Face.

The due date for submission of Budgetary Quotations for the subject work is extended up to 15:00 Hrs. on **13/12/2022**.

All other Terms & Conditions and BoQ & Scope of Work of Budgetary Enquiry letter dated 06/12/2022 (Ref.) for the subject work shall remain unaltered.

(Krishnamurthy D S)

Address for Communication:

Executive Engineer (M)III,
Administrative Building, 2nd Floor,
Room No.234,
New Mangalore Port Trust,
Panambur, Mangalore - 575010.
Mob: 9449700435, Ph: 0824-2887730

कार्यपालक अभियंता, (एम) III
Executive Engineer, (M) III
नव मंगलूर पत्तन प्राधिकरण
New Mangalore Port Authority
पणंबूर, मंगलूर - ५७५०१०
Panambur, Mangalore - 575 010