



NEW MANGALORE PORT AUTHORITY

(Ministry of Ports, Shipping & Waterways, Govt. of India)

Mechanical Engineering Department Electrical Engineering Division Administrative Building, New Mangalore Port Authority, Panambur, Mangalore- 575010	Contact Details: Website: http://www.newmangaloreport.gov.in E-mail: mahalingam.v@nmpt.gov.in Tel: 0824-2887750/740/739/736
---	---

NIT NO.: NMPA/Mech/EE(E)/2024/0976-1

TENDER DOCUMENT

FOR

“Providing illumination for the road near Godown No. 31 / PPP Hospital”

2025

LIST OF DOCUMENTS

Sl. No.	Description	Part	Page No.
1	Special Instructions to the Bidders for the E-Submission of the Bids Online Through E-Procurement Portal	PART - I	3 - 7
2	Tender Document	PART - II	8 - 79
3	Price Bid	PART- III	80 - 88
4	NMPA Bank Details	PART - IV	89
5	Checklist	PART - V	90

SPECIAL INSTRUCTIONS TO THE BIDDERS FOR THE E-SUBMISSION OF THE BIDS ONLINE THROUGH E-PROCUREMENT PORTAL

TENDER No: NMPA/Mech/EE(E)I/2024/0976-1

Dated: 06/02/2025

Name of Work: “Providing illumination for the road near Godown No. 31 / PPP Hospital”

1. बोलीदाता को होम पेज में उपलब्ध क्लिक हियर टू एनरोल का उपयोग करके पोर्टल में ऑनलाइन नामांकन करना चाहिए। फिर पोर्टल पर लॉग इन करने के बाद ई-टोकन के साथ डिजिटल सिग्नेचर एनरोलमेंट करना होगा। Bidder should do Online Enrolment in the Portal using the option Click Here to Enroll available in the Home Page. Then the Digital Signature enrollment has to be done with the e-token, after logging into the portal.
2. तत्पश्चात बोलीधारक नामांकन के दौरान चुने गए उपयोगकर्ता आईडी / पासवर्ड पोर्टल में लॉग इन कर पाएंगे। Bidder then logs into the portal giving user id / password chosen during enrollment.
3. दूसरों द्वारा दुरुपयोग न करते हुए पंजीकृत ई-टोकन का उपयोग बोलीदाता द्वारा ही किया जाना चाहिए। The e-token that is registered should be used by the Bidder and should not be misused by others.
4. किसी खाते में मैप किए जाने पर DSC को किसी अन्य खाते में दोबारा नहीं भेजा जा सकता है। यह केवल निष्क्रिय हो सकता है।
DSC once mapped to an account cannot be remapped to any other account. It can only be inactivated.
5. बोलीदाता अग्रिम रूप से अद्यतन कर सकते हैं, दस्तावेज़ जैसे प्रमाणपत्र, खरीद आदेश विवरण आदि, मेरे दस्तावेज़ विकल्प के तहत और इन्हें निविदा आवश्यकताओं के अनुसार चुना जा सकता है और फिर बोली जमा करने के दौरान बोली दस्तावेज़ों के साथ संलग्न किया जा सकता है। यह बोली दस्तावेज़ों के कम अपलोड को सुनिश्चित करेगा। The Bidders can update well in advance, the documents such as certificates, purchase order details etc., under My Documents option and these can be selected as per tender requirement and then attach them along with bid documents during bid submission. This will ensure easier upload of bid documents.
6. निविदा कार्यक्रम डाउनलोड करने / प्राप्त करने के बाद, बोलीदाता को सावधानीपूर्वक उनके माध्यम से जाना चाहिए और फिर निविदा दस्तावेज़ के अनुसार दस्तावेज़ जमा करना चाहिए; अन्यथा, बोली अस्वीकार कर दी जाएगी। After downloading / getting the tender schedules, the Bidder should go through them carefully and then submit documents as stated in the tender document; otherwise, the bid will be rejected.
7. बीओक्यू टेम्पलेट को बोलीदाता द्वारा संशोधित / प्रतिस्थापित नहीं किया जाना चाहिए और संबंधित कॉलम भरने के बाद उसे अपलोड किया जाना चाहिए, अन्यथा बोलीदाता उस निविदा के लिए अस्वीकार किए जाने के लिए उत्तरदायी है। बोलीदाताओं को केवल बिडर नाम और वैल्यू दर्ज करने की अनुमति है।

The BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bid is liable to be rejected. Bidders are allowed to enter the Bidder Name and Values only.

8. यदि कोई स्पष्टीकरण है, तो यह ई-प्रोक्योरमेंट पोर्टल के माध्यम से या निविदा दस्तावेज़ में दिए गए संपर्क विवरण के माध्यम से ऑनलाइन प्राप्त किया जा सकता है। बोलीदाता को पोर्टल पर ऑनलाइन या <http://eprocure.gov.in/eprocure/app> or <http://www.newmangaloreport.gov.in> पर बोली प्रस्तुत करने से पहले प्रकाशित किए गए कोरिगेंडम को ध्यान में रखना चाहिए, बोलीदाता को अग्रिम में बोली दस्तावेज़

तैयार करने चाहिए। निविदा अनुसूची में दर्शाए अनुसार प्रस्तुत किया जाना चाहिए और वे पीडीएफ प्रारूपों में होने चाहिए। If there are queries connected with this tender, have to be clarified online through the e-Procurement Portal, or through the contact details given in the tender document. Bidder should take into account the corrigendum published before submitting the bids online on the portal or on <http://eprocure.gov.in/eprocure/app> or <http://www.newmangaloreport.gov.in>. All documents to be submitted, as indicated in the tender schedule should be in PDF formats.

9. बोलीदाता को निविदा में निर्दिष्ट ईएमडी और निविदा शुल्क की व्यवस्था करनी चाहिए। मूल को (जैसा लागू हो) निविदा के लिए बोली जमा करने की तारीख और समय के भीतर, निविदा आमंत्रण प्राधिकारी को व्यक्तिगत रूप से पोस्टव्यक्तिगत रूप से दिया जाना चाहिए।/कूरियर/ Bidder should arrange for the EMD & tender fee (as applicable) as specified in the tender. The original should be posted/couriered/given in person to the Tender Inviting Authority, within the bid submission date and time for the tender.
10. बोली लगाने वाले को नियमों और शर्तों को पढ़ना चाहिए और बोलियों को जमा करने के लिए आगे बढ़ने के लिए उसी को स्वीकार करना चाहिए |
The Bidder should read the terms and conditions of the tender and accept the same before proceeding with submission to tender.
11. बोली प्रस्तुत करने की प्रक्रिया के दौरान किसी भी देरी या समस्या से बचने के लिए बोली लगाने वाले को निर्धारित समय से पहले निविदा दस्तावेजों को ऑनलाइन जमा करना चाहिए। The Bidder has to submit the tender document(s) online well in advance, before the prescribed time to avoid any delay or problem during the bid submission process.
12. सर्वर के अंत में अपलोड की गई फ़ाइल के आकार की कोई सीमा नहीं है। हालाँकि, अपलोड क्लाउंट सिस्टम पर उपलब्ध मेमोरी के साथ-साथ उस समय क्लाउंट साइड पर उपलब्ध नेटवर्क बैंडविड्थ पर तय किया जाता है। फ़ाइल का आकार कम करने के लिए, बोलीदाताओं को 75-100 DPI में दस्तावेजों को स्कैन करने का सुझाव दिया जाता है ताकि स्पष्टता बनी रहे और फ़ाइल का आकार कम हो जाए। यह बहुत कम बैंडविड्थ की गति पर भी त्वरित अपलोड करने में मदद करेगा | There is no limit on the size of the file that can be uploaded at the server end. However, the upload is dependent on the Memory available at the Client System as well as the Network bandwidth available at the client side at that point of time. In order to reduce the file size, bidders are suggested to scan the documents in 75-100 DPI so that the clarity is maintained and file size is optimum. This will help in quick uploading even at very low bandwidth speeds.
13. यह ध्यान रखना महत्वपूर्ण है कि, बोली लगाने वाले को फ्रीज बोली बटन पर क्लिक करना होगा, यह सुनिश्चित करने के लिए कि वह बोली प्रस्तुत करने की प्रक्रिया पूरी करता है। बोलियां, जो अवरूद्ध हुए नहीं हैं, को अपूर्ण / अमान्य बोलियों के रूप में मानकर तथा मूल्यांकन उद्देश्यों के लिए नहीं माना जायेगा।

It is important to note that, the bidder has to click on the Freeze Bid Button, to ensure that, Bid Submission Process is completed. Bids, which are not frozen, are considered as Incomplete/Invalid bids and are not considered for evaluation purposes.
14. स्थानीय मुद्दों के कारण बोलीदाताओं द्वारा ऑनलाइन बोली लगाने के दौरान किसी भी प्रकार की देरी या कठिनाइयों का सामना करने के लिए निविदा आमंत्रण प्राधिकरण (TIA) को जिम्मेदार नहीं ठहराया जाएगा।

The Tender Inviting Authority (TIA) will not be held responsible for any delay or the difficulties faced during submission of bids online by the bidders due to local issues.
15. बोलीदाता इस पोर्टल के माध्यम से ही बोली दस्तावेजों को ऑनलाइन मोड में जमा कर सकता है। इस प्रणाली के माध्यम से ऑफ़लाइन दस्तावेजों को संभाला नहीं जाएगा। तकनीकी बोली की केवल हार्ड कॉपी ईई (एम) III, एनएमपीटी को नियत तारीख से पहले पहुंचनी चाहिए। बोलीदाता यह सुनिश्चित करेगा कि न्यूनतम योग्यता से संबंधित सभी दस्तावेजों को तकनीकी बोली के साथ अनिवार्य रूप से अपलोड किया जाएगा, जिसमें असफल होने पर

बोली को अस्वीकार कर दिया जाएगा। The bidder may submit the bid documents in online mode only, through this portal. Offline documents will not be accepted. The bidder shall ensure that all the documents pertaining to minimum qualification shall be compulsorily uploaded along with the technical Bid failing which the bid shall be rejected.

16. बोली को फ्रीज करने के समय, ई-प्रोक्योरमेंट सिस्टम सभी बोली दस्तावेजों को अपलोड करने के बाद एक सफल बोली अपडेटिंग संदेश देगा और फिर बोली सारांश को बोली नंबर, तिथि और जमा करने के समय के साथ दिखाया जाएगा। अन्य सभी प्रासंगिक विवरणों के साथ बोली लगाएं। बोलीकर्ताओं द्वारा प्रस्तुत दस्तावेजों को बोलीदाता के ई-टोकन का उपयोग करके डिजिटल रूप से हस्ताक्षरित किया जाएगा और फिर प्रस्तुत किया जाएगा।

At the time of freezing the bid, the e-Procurement system will give a successful bid updating message after uploading all the bid documents submitted and then a bid summary will be shown with the bid no., date & time of submission of the bid along with all other relevant details. The documents submitted by the bidder should then digitally signed using the e-token of the bidder and then submitted.

17. बोली प्रस्तुत करने के बाद, बोली सारांश को प्रिंट करना होगा और बोली प्रस्तुत करने के टोकन के रूप में एक एक्रॉलेजमेंट के रूप में रखना होगा। बोली सारांश निविदा निविदा के लिए बोली प्रस्तुत करने के प्रमाण के रूप में कार्य करेगा और बोली उद्घाटन कार्यक्रम में भाग लेने के लिए प्रवेश बिंदु के रूप में भी कार्य करेगा।

After the bid submission, the bid summary has to be printed and kept as proof of submission of the bid. Entry to bid opening event will be restricted to bidders having proof of bid submission of the subject tender.

18. सिस्टम से सफल बोली प्रस्तुत करने का मतलब है, कि बोलीदाता द्वारा अपलोड की गई बोलियां प्राप्त होकर सिस्टम में संग्रहीत कर ली गयी हैं; सिस्टम इसकी शुद्धता के लिए प्रमाणित नहीं करता है। Successful bid submission means, the bids as uploaded by the bidder is received and stored in the system. System does not certify for correctness of the bid.

19. बोली लगाने वाले को यह देखना चाहिए कि प्रस्तुत किए गए बोली दस्तावेज वायरस से मुक्त हैं और यदि निविदा खोलने के दौरान वायरस के कारण दस्तावेज नहीं खुल पा रहे हैं तो बोली अस्वीकार कर दी जाएगी। इसके लिए आर्गेनाइजेशन जिम्मेदार नहीं होगी। The bidder should ensure that the bid documents submitted are free from virus. If NMPA is unable to open documents due to virus or any other reason during tender opening, the bid is liable to be rejected. NMPA will not be responsible for rejection of such bids.

20. टेंडर पोर्टल के शीर्ष पर सर्वर घड़ी से प्रदर्शित होने वाला समय, ई-प्रोक्योरमेंट पोर्टल में बोली प्रस्तुत करने, बोली खोलने आदि के अनुरोध के सभी कार्यों के लिए मान्य होगा। इस पोर्टल में अनुवर्ती समय भारतीय मानक समय (IST) के अनुसार है जो GMT + 5: 30 है। बोली लगाने के दौरान बोलीदाताओं को इस समय का पालन करना होगा। The time displayed from the server clock at the top of the tender Portal, will be valid for all actions of requesting bid submission, bid opening etc., in the e-Procurement portal. The Time followed in this portal is as per Indian Standard Time (IST) which is GMT+5:30. The bidders should adhere to this time during bid submission.

21. बोलीकर्ताओं से अनुरोध किया जाता है कि वे बोली प्रस्तुत करने की अंतिम तिथि और समय (सर्वर सिस्टम क्लॉक के अनुसार) से पहले निविदा प्रक्रिया के लिए ऑनलाइन ई-प्रोक्योरमेंट सिस्टम के माध्यम से निविदाएं प्रस्तुत करें। The bidders are requested to submit the bids through online e-Procurement system to the Tender Inviting Authority (TIA) well before the bid submission end date and time (as per Server System Clock).

22. निविदा प्रपत्र शुल्क और ईएमडी भाग I-तकनीकी बोली के साथ जमा किया जाएगा। शुल्क और ईएमडी के बिना जमा की गई बोली, जैसा कि ऊपर उल्लेख किया गया है, मूल्यांकन के लिए विचार नहीं किया जाएगा और खारिज कर दिया जाएगा। Tender form Fee and EMD shall be submitted with the Part I- Technical BID.

BID submitted without fees and EMD, as mentioned above will not be considered for evaluation and shall be rejected.

23. बोली लगाने वाला / निविदाकार / ठेकेदार कर विभागों के साथ लागू रिटर्न समय में दाखिल करेगा और दस्तावेजी प्रमाण के रूप में प्रस्तुत करना होगा। The Bidder/Contractor shall file the applicable returns with Tax departments in time and submit the same as documentary proof.
24. पोर्ट को क्रेडिट करने के लिए जीएसटी लागू टैक्स चालान में एक अलग लाइन आइटम के रूप में दिखाया जाएगा। The GST applicable shall be shown as a separate line items in the Tax invoices to avail input credit to Port.
25. ईएमडी / एलडी / एसडी को जब्त करने की स्थिति में, जीएसटी लागू है; तथा जुर्माना लगाने के दौरान जीएसटी लागू किया जायेगा।
In the event of forfeiting the EMD/SD GST is applicable and while imposing penalty/LD applicable GST shall be collected.

सूचकांक/INDEX

SI. No.	Description	Page No.
1	NOTICE INVITING TENDER.	8
2	INSTRUCTIONS TO BIDDERS	9
3	GENERAL CONDITIONS OF CONTRACT	22
4	SPECIAL CONDITIONS OF CONTRACT	45
5	SCOPE OF WORK & TECHNICAL SPECIFICATIONS	49
6	PARTICULARS OF BIDDER – ANNEXURE - 1	59
7	TENDER FORM – ANNEXURE - 2	60
8	FORM OF AGREEMENT – ANNEXURE - 3	62
9	FORMAT OF PERFORMANCE SECURITY DEPOSIT - BANK GUARANTEE – ANNEXURE - 4	64
10	FORMAT FOR DECLARATION – ANNEXURE - 5	67
11	FORMAT OF POWER OF ATTORNEY – ANNEXURE - 6	68
12	BANK INFORMATION FOR E-PAYMENT – ANNEXURE -7	70
13	DISPUTE REVIEW BOARD AGREEMENT – ANNEXURE-8	71
14	DETAILS OF ONGOING CONTRACTS ATNMPA-ANNEXURE-9	76
15	VERIFICATION OF LOCAL CONTENT – ANNEXURE-10	76
16	UNDERTAKING ON INDEMNIFICATION – ANNEXURE-11	77
17	INDEMNITY BOND - ANNEXURE - 12	78
18	BILL OF QUANTITIES	80
19	NMPA BANK DETAILS	89
20	CHECK LIST	90

SCHEDULE OF TENDER (SoT)**TENDER No: NMPA/Mech/EE(E)I/2024/0976-1****Dated: 06/02/2025****NOTICE INVITING TENDER**

(Through CPP Portal)

E-Tenders in two bid system are invited by New Mangalore Port Authority through Electronic tendering in CPP Portal i.e. <http://eprocure.gov.in/eprocure/app>

TENDER NO.	NMPA/Mech/EE(E)I/2024/0976-1
Name of the Work	“Providing illumination for the road near Godown No. 31 / PPP Hospital”
Mode of tender	Through CPP portal https://eprocure.gov.in/cppp/
Estimated cost	Rs.15,95,759/- (Rupees Fifteen Lakh Ninety Five Thousand Seven Hundred and Fifty Nine only) excluding GST.
Earnest Money Deposit	Rs.37,660/- (Rupees Thirty Seven Thousand Six Hundred Sixty only) inclusive of 18% GST ‘OR’ exemption certificate as per clause No 2.2.1(n) of ITB.
Tender Fees	Rs.560/- (Rupees Five Hundred Sixty only) inclusive of 12% GST - Non-refundable OR exemption certificate as per clause No 2.2.1(n) of ITB
Date of Tender Document available to parties to download	06/02/2025 at 18.00 Hrs.
Date of Starting of e-Tender for submission Bid on line at https://eprocure.gov.in/cppp/	06/02/2025 at 18:00 Hrs.
Date of closing of e-Tender for submission of Bid.	19/02/2025 at 15.00 Hrs.
Date & Time of opening of Technical Bids	20/02/2025 at 16.00 Hrs.
Date & Time of opening of Price Bid	Will be communicated separately to the qualified Bidders
Contract Period	2 Months from the date of execution of Contract Agreement within the specified time limit as per Tender.
Validity of Tender	120 days from the date of opening of Tender (Technical Bids)

Amendments to the tender (if any) will be issued only through web site <http://www.newmangaloreport.gov.in> and on CPP Portal www.eprocure.gov.in/eprocure/app

Sd/-

Executive Engineer (Ele)-I

2. INSTRUCTIONS TO THE BIDDERS (ITB)

2.1 SCOPE OF BID

E-Tenders in Two Cover system (Techno-Commercial Bid and Price Bid) are invited by Executive Engineer (E)I on behalf of New Mangalore Port Authority for the work of **“Providing illumination for the road near Godown No. 31 / PPP Hospital”**.

2.2 TENDER SUBMISSION:

The Tender shall be uploaded as follows:

2.2.1 **Technical Bid** shall contain the following:

- a) EMD in the form of Insurance Surety Bonds or Account Payee Demand Draft or Fixed Deposit Receipt or Banker’s Cheque or Bank Guarantee from any of the Commercial Banks or payment online is accepted.
- b) Earnest Money Deposit of **Rs.37,660/-**(Rupees Thirty Seven Thousand Six Hundred Sixty only) inclusive of 18% GST- NEFT Receipt shall be uploaded along with the Technical Bid **‘OR’** exemption certificate as per clause No 2.2.1(n) of ITB. Failure in submission of EMD will render the Bidders disqualified, except in the case as per clause No. 2.2.1 (n) below.
- c) TENDER FEE for **Rs. 560/-** (Rupees Five Hundred Sixty only) inclusive of 12% GST - non-refundable - NEFT Receipt shall be uploaded along with the Technical Bid **‘OR’** exemption certificate as per clause No 2.2.1(n) of ITB. Failure in submission of Tender fee will render the Bidders disqualified, except in the case as per clause No. 2.2.1 (n) below.
- d) All the documents should be as per the MQC. Technical Bid should not contain Price Bid. “Disclosure/indication of Price in the Technical Bid shall render the tender disqualified and rejected.
- e) The Tender document duly signed and sealed by the Bidder on each page along with Annexure duly filled along with amendments issued by NMPA if any.
- f) Particulars of Bidder - **Annexure – 1.**
- g) Supporting documentary evidence of work orders and also satisfactory completion certificate issued by the client,
- h) Tender Form - **Annexure - 2.**
- i) Form of Declaration – **Annexure – 5.**
- j) Power of Attorney - **Annexure – 6.**
- k) Bank Details of the Bidder for E-Payment – **Annexure - 7.**
- l) Copies of the **Valid Electrical Contract License, GST Registration Certificate, ESI & PF Registration and PAN card** to be submitted.
- m) Copies of profit and loss statements, balance sheet and Auditor’s report

for the last three years.

- n) Micro and Small Enterprises (MSE) registered with District Industries Centre (DIC) or Khadi and Village Industries commission or Khadi& Industries Board (KVIB) or Coir Board or National Small Industries Corporation (NSIC) or Directorate of Handicrafts and Handlooms or Udyog Aadhar memorandum or any other body specified by Ministry of MSME shall be exempted of EMD & Tender Fee on producing self attested supporting certificates along with Technical Bid.
- o) Dispute review Board – **Annexure - 8**
- p) Details of ongoing contracts at NMPA – **Annexure - 9**
- q) Verification of Local Content – **Annexure - 10**
- r) Undertaking on Indemnification – **Annexure - 11**
- s) Indemnity Bond – **Annexure -12**

2.2.2 **Price Bid shall be uploaded only through ONLINE:** Technical Bid and Price Bid shall be uploaded through online only. Price bid should be quoted in the BOQ template available in the CPP portal only. The BOQ template must not be modified/ replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for that tender. Bidders are allowed to enter the Bidder Name and Values only. Any condition imposed in the price bid shall make the tender liable for out-right rejection. The contract shall be for the whole works as described in the scope of work based on the priced Bill of Quantities submitted through CPP portal by the Bidder. The Bidder shall fill in rates and prices for all items of the works described in the Bill of Quantities through CPP portal. Items for which no rate or price is entered by the Bidder will not be paid for by the Port when executed and shall be deemed covered by the other rates and prices in the Bill of Quantities.

2.3 ELIGIBLE BIDDER:-

- 2.3.1 The invitation for bids is open only to all eligible Bidders meeting the eligibility criteria as defined in clause No.2.4
- 2.3.2 Tender Form information as per **Annexure-2**
- 2.3.3 Government owned Enterprises may only participate if they are legally and financially autonomous operate under commercial law and are not a dependent agency of the employer subject to fulfillment of minimum qualifying criteria.
- 2.3.4 Bidders shall not be under a declaration of ineligibility for corrupt and fraudulent practices issued by the employer in accordance with clauseNo.2.21

2.4 MINIMUM QUALIFICATION CRITERIA OF THE BIDDERS: (MQC)

2.4.1 FINANCIAL CRITERIA

The Bidder should have an average Annual financial turnover of **Rs.4,78,728/-** for the last 3 financial years 2021-22, 2022-23 & 2023-24

Note:- 1. Documentary evidence duly self-attested viz – **Auditor’s Certificates (with UDIN No)**/balance sheet / latest income tax return filed/profit and loss statement for the three years shall be uploaded along with the bid.

2. If the bidder is already having ongoing contracts in NMPA, then his combined work order value of all the ongoing contracts shall be deducted from his Financial Capacity. The Financial Capacity of the bidder shall be assessed from the Average Annual Financial Turnover of the Bidder for the last three years ending **March-2024**. The Bidder shall be technically qualified, only if his balance Financial Capacity after reduction, is equal to or more than the estimate put to tender.

{Example: If the Average Annual Turnover of the bidder is Rs.3,00,000/- (Rupees Three lakhs only), then the Financial Capacity of the Bidder is considered to be Rs.10,00,000/-(Rupees Ten lakhs only). If the contractor declares total ongoing works at NMPA of value Rs.4,00,000/- (Rupees Four lakhs only) in **Annexure-9**, then the contractor can Bid only for the remaining Financial Capacity i.e., Rs.6,00,000/-(Rupees Six lakhs only)}

2.4.2 TECHNICAL CRITERIA

The Bidder shall have successfully completed **Similar Works** during last 7 (Seven) years ending last day of month previous to the one in which tenders are invited should be either of the following:

One similar completed work costing not less than **Rs.12,76,607/-**
(Excluding GST)

OR

Two similar completed works each costing not less than **Rs.7,97,880/-**
(Excluding GST)

OR

Three similar completed works each costing not less than **Rs.6,38,304/-**
(Excluding GST)

“Similar Work” means **“Supply, Installation, Testing & Commissioning of High Mast Tower and associated works (or) HT/LT Electrical works which includes Supply, Installation, and Testing & Commissioning of High Mast Towers”**.

Note: In case of Composite work, amount pertaining to similar works mentioned above will only be considered for evaluation.

- i) In order to meet the Technical criteria as per clause No.2.4.2.(i) above, the bidder shall submit the following documents along with the technical bid:-
 - a. Self-attested photocopies of LOA/Work Order/Agreements showing the awarded contract value for “similar works” and satisfactory Completion Certificates issued by the Client, indicating the date of Completion and completed Contract Value. The Bidder shall also enclose detailed BOQ with rates and scope of work supporting the LOA/work order/agreements/completion certificates. TDS certificate clearly showing the tax deduction from client for related work orders/agreements shall be attached for verification.
 - b. **If the similar work carried out on sub-contract basis, then permission obtained by the prime contractor from the client for sub-contracting should be submitted.**
 - c. **Work Order/Work Completion Certificate submitted by the bidder will be sent for client confirmation.**
- ii. The Bidder shall have **Valid Electrical Contract License** in the same name (Bidder’s name) and same should be uploaded along with the Technical Bid.

2.4.3 Even though the Bidders meet the qualifying criteria as per clause 2.4, they are subject to be disqualified and debarred for a period of two (2) years from participating for tenders at New Mangalore Port Authority duly informing the MSME authorities if applicable, if they have:

- i. made misleading or false representations in the forms, statements and attachments submitted in proof of the qualification requirements; and/or
- ii. Record of poor performance such as abandoning the works, not properly completing the contract, inordinate delays in completion or financial failures etc.

2.5 LAST DATE FOR SUBMISSION OF TENDER: NMPA may at its sole discretion reserves the right to extend the date for receipt of tender.

2.5.1 **RATES TO BE INCLUDED FOR ALL OPERATIONAL EXPENSES:**

- i. The contractor may visit the Port Authority area before quoting. The Bidder should quote the rate by taking into consideration all expenses.
- ii. The GST as applicable will be paid extra by the Port. The GST Registration Number of the Bidder shall be furnished invariably in the tender as well as the Bills/Invoices. Copy of GST registration certificate shall be enclosed along with the tender.
- iii. GST will be paid on production of documentary proof of registration with the Central Excise Department only.

2.6 AUTHORITY IN SIGNING TENDER DOCUMENTS:

- i. The tender, if submitted on behalf of a Partnership Firm should be signed either by all the partners or some of the partners or other person/s holding a valid “Power of Attorney” from other partners or all the partners constituting the firm.
- ii. In case of a Company, the tender should be signed by a person holding a valid Power of Attorney executed in his favour in accordance with the constitution of the Company.

2.7 ONE BID PER BIDDER

2.7.1 Each bidder shall submit only one bid for one package. A bidder who submits or participates in more than one Bid (other than as a subcontractor or in cases of alternatives that have been permitted or requested) will cause all the proposals with the Bidder's participation to be disqualified.

2.7.2 A Bidder shall not have a conflict of interest. All Bidders found to have conflict of interest shall be disqualified. Bidders may be considered to have a conflict of interest with one or more parties in this Tendering process, if they are or

- a. have been associated in the past, with a firm or any of its affiliates which have been engaged by the Employer to provide consulting services for the preparation of the design, specifications, and other documents to be used for the services to be rendered under these Tendering Documents ; or
- d. Submit more than one Tender in this Tendering process.
- i. A Bidder that is under a declaration of ineligibility by the Employer in accordance with ITB Clause 2.21, at the date of contract award, shall be disqualified.
- ii. Bidders shall provide such evidence of their continued eligibility satisfactory to the Employer, as the Employer shall reasonably request.

2.8 BIDDER TO INFORM HIMSELF FULLY

2.8.1 The Bidder is expected to examine carefully the contents of all the documents provided like instructions to the Bidders, Tender Conditions, Scope of work etc. Failure to comply with the requirements of the tender will be at the Bidders own risk. The Bidder to ensure to make a complete and careful examination of requirements and other information set out in the tender document. The Bidder shall be deemed to have, visited the site and surroundings and have obtained all necessary information in all the matters whatsoever that might influence while carrying out the Works as per the conditions of the tender and to satisfy himself to sufficiency of his tender etc.

2.8.2 The Bidder shall examine carefully the conditions of contract in the Tender documents supplied herewith. Though every effort is made herein to give basic data as exhaustively as possible, the Bidder is advised to visit the New Mangalore Port and its approaches and get himself thoroughly acquainted with all necessary data concerning weather conditions, working conditions, sea conditions, etc. for the purposes of making a correct offer. All costs, charges and expenses that may be incurred by the Bidder in connection with such investigations for the submission of his offer shall be borne by him and the Board accepts no liability or responsibility whatsoever therefore.

2.8.3 Bidder shall bear all costs associated with the preparation and submission of his tender and NMPA will in no case be responsible or liable for these costs, regardless of the conduct or outcome of the tendering process.

2.9 Earnest Money Deposit:

2.9.1 The tender shall be accompanied by proof of Earnest Money deposit of **Rs.37,660/-**(Rupees Thirty Seven Thousand Six Hundred Sixty only) inclusive of 18% GST 'OR' exemption certificate as per clause No 2.2.1(n) of ITB. EMD in the form of Insurance Surety Bonds or Account Payee Demand Draft or Fixed Deposit Receipt or Banker's Cheque or Bank Guarantee from any of the Commercial Banks or payment online is accepted. The tender without EMD shall be rejected, except in the case as per clause No.2.2.1 (n).

2.9.2 In the event of Tenderer withdrawing his tender before the expiry of tender validity period of **120 days** from the date of opening, the tender shall be cancelled and EMD shall be forfeited. **Applicable GST shall be recovered on forfeiture of EMD.**

2.9.3 The Earnest Money Deposit of unsuccessful Tenderers shall be returned without interest as early as possible on award of Contract to the successful Tenderer. The Earnest Money Deposit of the successful Tenderer shall be refunded (without interest) only on receipt of **Security Deposit cum Performance Guarantee** as stipulated in the tender clause **2.20**. In the event of forfeiting of EMD/LD/SD and while imposing penalty GST shall be collected.

2.9.4 NMPA reserves the right to forfeit the Earnest Money Deposit in respect of successful Tenderer, if he fails to enter into a Contract and furnish the necessary Bank Guarantee or security towards performance within **21 days** from the date of issue of **Letter of Acceptance**, otherwise penalty @ 0.25% of the amount of the Performance Guarantee for each week or part thereof for the number of weeks delayed beyond the stipulated date of submission shall be levied maximum up to 2.5% of the amount of the Performance Bank Guarantee.

2.9.5 In the event of forfeiting the Performance Security, GST is applicable and while imposing penalty & Liquidated damages GST as applicable shall be collected.

2.9.6 The bidder shall be disqualified/terminated duly forfeiting EMD (if applicable) and may be debarred for a period of two (2) years from participating for tenders at New Mangalore Port Authority duly informing the MSME authorities if applicable, if

- i. The Bidder withdraws the Bid after Bid opening during the period of Bid Validity;

2.9.7 The successful Bidder fails within the specified time limit to:

- i. Sign the Agreement AND / OR furnish the required Performance security.
- ii. Fail to commence the work on the specified date as per LOA/Work order.
- iii. If the bid is varied or modified in a manner not acceptable to the Employer during the validity or extended validity period duly agreed by the Bidder.
- iv. If any information or representation submitted by Bidder is found to be false or incorrect.
- v. Any effort by the Bidder to influence the Employer on bid evaluation, bid comparison or contract award decision.

2.10 TENDER VALIDITY: The tender shall remain valid for acceptance for a period of 120 days from the date of opening of Technical Bid. NMPA reserves their right to extend the period of validity for a specific time. The request and the response, thereto, shall be made in writing by post or by Fax/e-mail. A bidder may refuse the request which may be accepted by NMPA. However, in the event of the Bidder agreeing to the request; he shall not be permitted to modify his tender.

2.11 AMENDMENTS:

2.11.1 At any time, prior to the last date for submission of tenders, NMPA reserves the right to amend and modify the tender document by issuing Addendum/Corrigendum which shall be uploaded in the CPP/PORT Websites.

2.11.2 The Addendum/Corrigendum so issued shall form part of the Contract and shall be binding upon the Bidders. NMPA may at their discretion, extend the last date for submission of the tender, to enable the Bidders to have reasonable time to submit their tender after taking into consideration such amendments, which shall also be uploaded to the Websites. The Bidder shall acknowledge receipt of such Addenda/Corrigenda and submit the same along with his Tender duly signed and

sealed in all pages.

2.12 LANGUAGE OF TENDER :

The Tender submitted by the Bidder and all correspondence and documents relating to the Tender exchanged by the Bidder and the NMPA shall be written in the *English language*. Any printed literature, other than English language, shall be accompanied by an English translation, in which case, for purpose of interpretation of the tender, the English translation shall govern.

2.13 MODIFICATION, SUBSTITUTION AND WITHDRAWAL OF PROPOSAL:

No offer shall be modified, substituted or withdrawn by the Bidder after the closing time on due date. Withdrawal of a proposal during the interval between closing time on proposed due date and expiry of the proposal validity period would result in disqualification of the bidder as per clause 2.9 of Tender Document.

2.14 TENDERED CURRENCIES:

Prices shall be quoted in Indian Rupees only and all payments will be made in Indian Rupees.

2.15 PRE BID QUERIES

Not Applicable

2.16 TENDER OPENING AND EVALUATION:

2.16.1 **OPENING OF TECHNICAL BID:** Technical bids of the Tender, received up to closing time on stipulated date, shall be opened as per the Important Instructions of CPP.

2.16.2 **SCRUTINY AND EVALUATION OF THE TENDER**

- i. Prior to the detailed evaluation of bid, the employer will determine whether each bid (a) meets the eligibility criteria defined at 2.3 & 2.4 above (b) has been properly signed by an authorized signatory holding Power of Attorney in his favor (c) accompanied by Tender fee (if applicable), EMD (if applicable) and (d) is responsive to the requirement of the bidding documents. If any of the above conditions are not satisfied, the bid shall be rejected outright.
- ii. Conditional offer or alternative offers will not be considered further in the process of tender evaluation.
- iii. A substantially responsive technical and Financial Bid is one which

conforms to all the terms, conditions and specifications of the bidding documents, without material deviation. A material deviation or reservation is one (a) which affects in any substantial way the scope, quality or performance of the works; (b) which limits in any substantial way, the employers right or bidders obligations under the contract or (c) whose rectification would affect unfairly the competitive position of others bidders presenting responsive bids. The Bidder who does not fulfill the tender requirements shall not be considered for further evaluation.

- iv. After the tender opening, the whole process involving scrutiny, clarifications, evaluation and comparison of tenders and recommendations regarding award of Contract shall be confidential. Any efforts on part of any Bidder to influence the Port Authority in any way in the process of scrutiny, evaluation, comparison of tenders and decision concerning award of Contract may result in rejection of the Bidder's bid.
- v. To assess the scrutiny, evaluation and comparison of tenders, the Port Authority may ask Bidder individually for clarifications. Clarifications shall be sought only on the documents submitted along with the bid. No new documents/work orders shall be entertained which was not part of the original submission whose acceptance would affect unfairly the competitive position of others bidders presenting responsive bids. Request for clarification and response thereto shall be in writing/email or through fax. If the Bidder fails to submit the requested documents within the time specified by the department, his bid is liable to be rejected. No change in Price or substance of the tender shall be sought, offered or permitted nor is the Bidder permitted to withdraw the tender before the expiry of the validity period of the tenders in the process of clarifications.
- vi. If a Technical Bid is not substantially responsive, it will be rejected by the employer, and may not subsequently be made responsive by correction or withdrawal of the non-conforming deviation or reservation. The Price/Financial Bid of those bidders shall not be opened.

2.16.3 **OPENING OF PRICE BID:**

- i. Tenders, which are found to be in conformity with NMPA's Tender requirement, shall be considered for opening of Price Bid.
- ii. The Bidders found to be qualified and responsive shall be informed about the date and time of opening of their Price Bids. On the stipulated date and time the Price Bids of such Bidders shall be opened online.
- iii. The Bidders has to quote the rate for the subject work in the price Bid format- PART III excluding GST.
- iv. The evaluation shall be done on the basis of **total lowest value (L1)** quoted. The GST element if any will **not be considered for comparison**.
- v. Further, in order to promote the Make in India Initiative by the Government of India, Class 1 Local suppliers shall get purchase preference over Class II local suppliers as well as Non-Local supplier as per the following procedure (Refer GCC Clause 3.1 definitions):-
 - a. Among all qualified bids, the lowest bid will be termed as L1, if L1

- is Class I Local supplier, the contract will be awarded to L1.
- b. If L1 is not a Class-I Local Supplier, the lowest bidder among the Class-I local supplier, will be invited to match the L1 price subject to Class-I local Supplier's quoted price falling within the margin of Purchase preference, and the contract shall be awarded to such Class-I Local supplier subject to matching the L1 price.
 - c. In case such Lowest eligible Class- I local supplier fails to match the L1 price, the Class-I local supplier with the next higher bid within the margin of purchase preference shall be invited to match the L1 price and so on and contract shall be awarded accordingly. In case none of the Class I supplier within the margin of purchase preference matched the L1 price, the contract may be awarded to the L1 bidder.

Note: The Class-I local supplier/Class-II Local Supplier shall submit the self attested copy of Annexure-11 compulsorily along with the Bid clearly indicating the percentage of local content (local staffs that the contractor shall be deploying, in case the contract is awarded to him) and provide self-certification that the services/items offered meets the local content requirement for Class I supplier/Class II local supplier, as the case may be.

- vi. The Bidder, whose bid is accepted by the Port Authority, shall be duly informed in writing. Within 7 days of receipt of intimation, regarding acceptance of its bid, the Bidder shall submit draft Contract agreement in the format approved by the Port Authority as in the **ANNEXURE-3** of Tender Document, and within a week thereafter the Contract agreement shall be signed between the Port Authority and the successful Bidder.
- vii. If the Bid of the successful Bidder is seriously unbalanced in relation to the Engineer or his Representative's estimate of the cost of work to be performed under the contract, the Employer may require the Bidder to produce detailed price analysis for any or all items of the Bill of Quantities, to demonstrate the internal consistency of those prices with the implementation/construction methods and schedule proposed.
- viii. Offers, deviations & other factors which are in excess of the requirement of the Tender document or otherwise result in the accrual of unsolicited benefits to the Employer shall not be taken into account in Tender evaluation.
- ix. **The price Bid with any counter conditions will be summarily rejected.**

2.17 AWARD OF CONTRACT:

Award Criteria: The employer will award the contract to the L1 Bidder whose bid has been determined to be responsive to the bidding documents and who has offered the lowest evaluated Bid Price, provided that such bidder has been determined to be (a) eligible in accordance with the provisions of Clause

No.2.3 and (b) qualified in accordance with the provisions of clause No.2.4.

2.18 EMPLOYERS RIGHT TO ACCEPT ANY BID AND TO REJECT ANY OR ALL:

Notwithstanding Clause No.2.17, the employer reserves the right to accept or reject any bid and to cancel the bidding process and reject all bids, at any time prior to the award of contract, without thereby incurring any liability to the affected bidder or bidders on the grounds for employer's action. Further, NMPA does not bind them to accept the lowest offer.

2.19 NOTIFICATION OF AWARD AND SIGNING OF AGREEMENT

- i. The bidder whose bid has been accepted will be notified of the award by the employer prior to expiration of the bid validity period. This letter (herein after and in the conditions of contract called the "letter of acceptance") will state the sum that the employer will pay the contractor in consideration of the execution completion and maintenance of the works by the contractor as prescribed by the contract (hereinafter and in the contract called the "contract price").
- ii. The notification of award will constitute the formation of the contract subject only to the furnishing of a performance security in accordance with the provision of clause 2.20.
- iii. The agreement will incorporate all correspondence between the employer and the successful bidder. The Contractor shall enter into and execute the Contract Agreement, to be prepared and completed at the cost of the Contractor, in the **Annexure-3** with such modifications as may be necessary within **14 Days** from the Date of issue of LOA. The Agreement to be executed on a non-judicial Stamp paper of value **Rs.500/- issued from Mangaluru jurisdiction. The Bidder shall submit 10 sets of Agreement copies at his own cost.**

2.20 PERFORMANCE SECURITY:

Performance security for a sum equivalent of **10%** of the total contract value including GST shall be submitted in the form of Insurance Surety Bonds or Account Payee Demand Draft or Fixed Deposit Receipt from a Commercial Bank or Bank Guarantee from a Commercial Bank or online payment are accepted in the approved format **within 21 days** from the date of issue of LOA. The Performance security shall be kept valid for the total contract period and Guarantee for two year plus Three Months claim Period. Thereafter, the total of 10% of Performance Security shall be released to the Contractor after successful completion of the Guarantee Period, deducting any dues payable to the Port. Failure to comply with the above shall lead to termination of contract as per clause No. 2.9 of ITB. If the contract is extended on mutual consent at the same rates, terms and conditions of the contract, then the Performance security shall also be extended for the same period plus Three Months claim period.

Note:- i) The Penalty for the delay in submission of the Performance Guarantee within the stipulate date above shall be at the rate of 0.25% of the amount of performance guarantee for each week or part of the week for the number of weeks delayed beyond the stipulated date of submission.

ii)The performance security shall be complied as per the orders/amendments issued by the Authorities.

“The Contractor shall furnish the BG towards performance security by the issuing bank directly to the Port through SFMS mode with ICICI Bank IFSC code: ICIC000014.

This will not bear any interest. Bank Guarantee, obtained from the Nationalized Bank/Scheduled bank in the format prescribed shall be in compliance with for a digital confirmation for the Bank Guarantee and the BG not complying with this shall not be considered”

2.21 CORRUPT OR FRAUDULENT PRACTICES

The Employer requires that Bidders/Suppliers/Contractors under this contract, observe the highest standard of ethics during the procurement and execution of this contract. In pursuance of this policy, the Employer

i. defines, for the purpose of these provisions, the terms set forth below as follows:

a. "corrupt practice" means the offering, giving, receiving or soliciting of anything of value to influence the action of a public official in the procurement process or in contract execution; and

b. "fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the Employer, and includes collusive practice among Bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the Employer of the benefits of free and open competition.

ii. Will reject a proposal for award of work if he determines that the Bidder recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question.

iii. Will declare a Bidder ineligible, either indefinitely or for a stated period of time, to be awarded a contract/contracts if he at any time determines that the Bidder has engaged in corrupt or fraudulent practices in competing for, or in executing, the contract.

2.22 THE LAW, WHICH APPLIES TO THE CONTRACT:

The Contract shall be governed by the Indian Contract Act and under the Indian Law. The Arbitration for settlement of disputes shall be held in Mangalore, Karnataka, India.

Apart from the above, conciliation through conciliation committees/ councils comprising of independent subject experts may also be explored to settle the disputes.

*** **

3 GENERAL CONDITIONS OF CONTRACT

A: GENERAL:

3.1 DEFINITIONS:

Terms which are defined in the Contract Data are not also defined in the Conditions of Contract but keep their defined meanings. Capital initials are used to identify defined terms;

- i. **Bill of Quantities** means the priced and completed Bill of Quantities forming part of the Bid.
- ii. **Compensation Events** are those defined in Clause No.3.30.
- iii. The **Completion Date** is the date of completion of the Works as certified by the Engineer or his nominee in accordance with Clause No.3.36.
- iv. The **Contract** is the contract between the Employer and the Contractor to execute, complete and maintain the Works. It consists of the documents listed in Clause No. 3.2(iii).
- v. The **Contract Data** defines the documents and other information which comprise the Contract.
- vi. The **Contractor** is a person or corporate body whose Bid to carry out the Works has been accepted by the Employer.
- vii. The **Contractor's Bid** is the completed Bidding documents submitted by the Contractor to the Employer.
- viii. The **Contract Price** is the price stated in the letter of acceptance and thereafter as adjusted in accordance with the provisions of the Contract.
- ix. **Days** are calendar days, **months** are calendar months.
- x. A **Defect** is any part of the Works not completed in accordance with the Contract.
- xi. The **Defects Liability Period** is the period named in the Contract Data and calculated from the Completion Date.
- xii. The **Employer** is the party who will employ the Contractor to carry out the Works.
- xiii. The **Site** is the area defined as such in the Contract Data.
- xiv. The **Intended Completion Date** is the date on which it is intended that the Contractor shall complete the works. The Intended Completion Date

is specified in the Contract Data. The Intended Completion Date may be revised only by the Engineer or his nominee by issuing an extension of time.

- xv. **Materials** are all supplies, including consumables, used by the contractor for incorporation in the Works.
- xvi. The **Engineer or his nominee** is the person named in the Contract Data (or any other competent person appointed and notified to the contractor to act in replacement of the Engineer or his nominee) who is responsible for supervising the Contractor, administering the Contract, certifying payments due to the Contractor, issuing and valuing Variations to the Contract, awarding extensions of time and valuing the Compensation Events.
- xvii. **Specification** means the Specification of the Works included in the Contract and any modification or addition made or approved by the Engineer or his nominee.
- xviii. The **Start Date** is given in the Contract Data. It is the date when the Contractor shall commence execution of the works. It does not necessarily coincide with any of the Site Possession Date.
- xix. A **Variation** is an instruction given by the Engineer or his nominee which varies the Works.
- xx. The **Works** are what the Contract requires the Contractor to Supply, install and turn over to the Employer as defined in the Contract Data.
- xxi. **“Local Content”** means the amount of value added in India which shall unless otherwise prescribed by the Nodal Ministry, be the total value of the item procured (excluding net domestic indirect taxes) minus the value of imported content in the item (including all customs duties) as a proportion of the total value, in percent.
- xxii. **“Class – I local supplier”** means a supplier or service provider, whose goods, services or works offered for procurement, has local content equal to or more than 50%.
- xxiii **“Class – II Local Supplier”**
means a supplier or service provider, whose goods, services or works offered for procurement, has local content more than 20% but less than 50%.
- xxiv **“Non Local supplier”** means a supplier or service provider, whose goods, services or works offered for procurement, has local content less than or equal to 20%.
- xxv **“Margin of purchase preference”** means the maximum extent to which the price quoted by a Class – I local supplier may be above the L1 for the purpose of purchase preference, which shall be 20%.

- xxvi **“L1”** means the lowest tender or lowest bid or the lowest quotation received in a tender, bidding process or other procurement solicitation as adjudged in the evaluation process as per the tender or other procurement solicitation.
- xxvii **“Nodal Ministry”** means the Ministry or Department identified pursuant to this order in respect of a particular item of goods or services or works.
- xxviii **“Procurement entity”** means a Ministry or Department or attached or subordinate office of or autonomous body controlled by, the Government of India and includes Government companies as defined in the companies act.

3.2 INTERPRETATION:

- i. In interpreting these Conditions of Contract, singular also means plural, male also means female or neuter and the other way around. Headings have no significance. Words have their normal meaning under the language of the Contract unless specifically defined. The Engineer or his nominee will provide instructions clarifying queries about the Conditions of Contract.
- ii. If sectional completion is specified in the Contract Data, references in the Conditions of Contract to the Works, the Completion Date, and the Intended Completion Date apply to any Section of the Works (other than references to the Completion Date and Intended Completion date for the whole of the Works).
- iii. The documents forming the Contract shall be interpreted in the following order of priority:
 - a. Agreement
 - b. Letter of Intent and work order.
 - c. Contractors Bid
 - d. Contract Data
 - e. Conditions of Contract including Special Conditions of Contract.
 - f. Specifications
 - g. Drawings, if any
 - h. Bill of quantities and
 - i. any other documents listed in the Contract Data as forming part of the Contract.

3.3 LANGUAGE AND LAW:

The language of the Contract and the law governing the Contract are stated in the Contract Data.

3.4 ENGINEER OR HIS NOMINEES DECISION:

Except where otherwise specifically stated, the Engineer or his nominee will decide contractual matters between the Employer and the Contractor in the role representing the Employer.

3.5 DELEGATION: The Engineer or his nominee may delegate any of the duties and responsibilities to other people after notifying the Contractor and may cancel any delegation after notifying the Contractor.

3.6 COMMUNICATIONS: Communications between parties which are referred to in the conditions are effective only when in writing. A notice shall be effective only when it is delivered (in terms of Indian Contract Act 1872).

3.7 PERSONNEL: The Contractor shall employ the personnel as Onsite Support Resource as referred to in the Contract Data to carry out the functions stated in the Schedule or other personnel approved by the Engineer or his nominee. The Engineer or his nominee will approve any proposed replacement of key personnel only if their qualifications, abilities, and relevant experience are substantially equal to or better than those of the personnel listed in the schedule.

If the Engineer or his nominee asks the contractor to remove a person who is a member of the contractor's staff of his work force stating the reasons, the contractor shall ensure that the person leaves the site within seven days and has no further connections with the work in the contract.

3.8 EMPLOYERS AND CONTRACTORS RISKS:

The Employer carries the risks which this Contract states are Employer's risks and the contractor carries the risks which this Contract states are contractor's risks.

3.9 EMPLOYERS RISKS:

The Employers risks are;

- a. in so far as they directly affect the execution of the Works in the country where the Permanent Works are to be executed:
 1. war and hostilities (whether war be declared or not), invasion, act of foreign enemies;
 2. rebellion, revolution, insurrection, or military or usurped power, or civil war;
 3. ionizing radiations, or contamination by radioactivity from any nuclear fuel, or from any nuclear waste, from the combustion of nuclear fuel, radioactive toxic explosive or other hazardous properties of any explosive nuclear assembly or nuclear component thereof;
 4. pressure waves caused by aircraft or other aerial devices travelling at sonic or supersonic speeds; and
 5. riot, commotion or disorder, unless solely restricted to the employees of the Contractor or of his Subcontractors and arising from the conduct of the Works;
 6. Unforeseen Rains (Rains if any; during the period other than the Monsoon period as stated in the Tender), floods, tornadoes, earthquakes and landslides.

- b. loss or damage due to the use or occupation by the Employer of any Section or part of the Permanent Works, except as may be provided for in the Contract;
- c. loss or damage to the extent that it is due to the design of the Works, other than any part of the design provided by the Contractor or for which the Contractor is responsible; and
- d. any operation of the forces of nature (in so far as it occurs on the Site) which an experienced contractor:
 - 1. could not have reasonably foreseen, or
 - 2. could reasonably have foreseen, but against which he could not reasonably have taken at least one of the following measures:
 - A. prevent loss or damage to physical property from occurring by taking appropriate measures, or
 - B. Insure against.

3.10 CONTRACTORS RISKS:

All risks of loss of or damage to physical property and of personal injury and death which arise during and in consequence of the performance of the Contract other than the excepted risks are the responsibility of the Contractor.

3.11 INSURANCE:

The insurance shall be as follows;

- 1. All the materials shall stand insured in the name of New Mangalore Port Authority from the time of arrival at site till commencement of installation against fire, pilferage and damage for the value of 90% of each item. The charges for the insurance shall be borne by the Contractor.
- 2. During erection and till the work is completed and satisfactory taken over by the N.M.P.A after testing the materials shall stand covered by suitable erection Insurance also for the value of 110% of the item. The charges for the insurance shall be borne by the Contractor.
- 3. All the men/women to be deployed by the Contractor for performing the contract shall be insured against injury/accidents/death by the Contractor at his own cost.
- 4. The Contractor shall indemnify New Mangalore Port Authority against all losses and claims In case of death or injury caused to any person by him during the execution of the work.
- 5. The Contractor shall effect and maintain the following policies at no cost to NMPA, during Contract period with an Indian Insurance Company approved by Insurance Regulatory Development Authority of India (IRDA).

i. Commercial General Liability (CGL):

The Contractor is required to take a Commercial General Liability (CGL) Insurance policy during execution of contract work to the extent of 50% of the contract value to cover Third party Liability with cross liability extension. The following third party liabilities shall be covered;

- a. Third party bodily injuries / death / disablement (persons not belonging to Employer and/or Contractors.
- b. Third party Property damage which includes damages to others materials/pipeline/argo/inventories/equipment/other facilities belonging to third party and inclusive of properties during construction/erection/ Government properties.
- c. The value of third party legal liability for compensation for loss of human life or partial / total disablement as well as for damage to others equipment/material/property shall be of required statutory limit where applicable or as awarded by Court of Law.

The policy will be on claim made basis with retroactive date from the date of commencement of the contract and shall be valid throughout the tenure of the contract period (including defect liability period) and be also valid during the extended period if any.

The policy will be having claim series clause and extended notification clause with cross liability extension.

ii. Employer Liability Insurance:

The Contractor shall indemnify and keep indemnified the Employer against all damages or compensation payable at Law in respect of or in consequence of any accident or injury to any workman or other person in the employment of the Contractor or Sub-Contractor against all claims, demands, proceedings, costs, charges and expenses whatsoever in respect thereof or in relation thereto and the Employer shall be at liberty to deduct or adjust from the Contractor's bills an amount that Employer may be called upon to pay towards claims, demands, proceedings, costs, charges and expenses whatsoever in respect of or in relation to any accident or injury referred to above without any reference to the Contractor.

The Contractor shall be registered under ESI as per the relevant statute and act and shall continue such insurance till completion of the Contract covering all the employees / workers / casual labour/contract labour/outsourced persons under his supervision deputed for the said contract work. The Contractor shall also submit such policy of insurance as and when required by the Employer / Employers representatives.

iii. Automobile Liability Insurance: Covering use of vehicles / mobile equipments used by Contractor or sub-contractor(s) (whether or not owned by them) in connection with the execution of the contract.

iv. Claim Lodgement: In all cases the Contractor shall lodge the claim with the underwriters and also settle the claims. All claims shall be settled in India. However, the Contractor shall proceed with the repairs and/or replacement of the damaged structures / facilities without waiting for the settlement of the claims. In case seizure of materials by concerned authorities the Contractor shall arrange prompt release against bond, securities or cash as required.

The Contractor will indemnify to the fullest extent permitted by law and keep the Employer, its officers, employees and other related parties hold harmless from all claims for bodily injury and property damage that may arise from the performance of the work.

3.12 THE WORKS TO BE COMPLETED BY THE INTENDED COMPLETION PERIOD:

The Contractor may commence execution of the works on the Start Date and shall carry out the works in accordance with the Bar Chart submitted by the contractor as updated with the approval of the Engineer or his nominee, and complete them by the Intended Completion Date.

3.13 SAFETY: The Contractor shall be responsible for the safety of all activities on the Site.

3.14 POSSESSION OF THE SITE:

The Employer shall give possession of all parts of the Site to the Contractor, free from encumbrances. If possession of a part is not given by the start date stated in the Contract Data the Employer is deemed to have delayed the start of the relevant activities and this will be a Compensation Event.

3.15 ACCESS TO THE SITE:

The Contractor shall allow the Engineer or his nominee and any person authorized by the Engineer or his nominee access to the Site to any place where work in connection with the Contract is being carried out or is intended to be carried out and to any place where materials or plant are being manufactured, fabricated and/or assembled for the works.

3.16 INSTRUCTIONS:

The Contractor shall carry out all instructions of the Engineer or his nominee which comply with the applicable laws where the Site is located.

3.17 DISPUTES:

If the Contractor believes that a decision taken by the Engineer or his nominee was either outside the authority given to the Engineer or his nominee by the Contract or that the decision was wrongly taken, the decision shall be referred to the Dispute Review Board (DRB) within 28 days of the notification of the Engineer or his nominee's decision.

3.17.1 SETTLEMENT OF DISPUTES:

If a dispute of any kind whatsoever arises between the Employer and the Contractor in connection with, or arising out of the Contract or the execution of the Works, whether during the execution of the Works or after their completion and whether before or after repudiation or after termination of the Contract, including any disagreement by either party with any action, inaction, opinion, instruction, determination, certificate or valuation of the Engineer or his nominee, the matter in dispute shall, in the first place be referred to the Disputes Review Board [DRB].

Unless the Contract has already been repudiated or terminated or frustrated the Contractor shall in every case, continue to proceed with the Works with all due diligence and the Contractor and the Employer shall give effect forthwith to every decision of the Engineer or his nominee unless and until the same shall be revised, as hereinafter provided, in a Dispute Review Board Recommendation / Arbitral Award.

3.17.2 **Arbitration:** Any dispute in respect of in respect of contracts where party is dissatisfied by the Dispute Review Board's (DRB) decision shall be decided by arbitration as set forth below:

- i) A dispute with contractor shall be finally settled by arbitration in accordance with the Indian Arbitration and Conciliation Act, 1996, or any statutory amendment thereof. The arbitral tribunal shall consist of 3 arbitrators, one each to be appointed by the Employer and the contractor, and the third to be appointed by the mutual consent of both the arbitrators, failing which by making a reference to CIDC-SIAC Arbitration Center from their panel.
- ii) Neither party shall be limited in the proceedings before such arbitrators to the evidence or arguments already put before the Engineer or his nominee or the Board, as the case may be, for the purpose of obtaining said recommendations/decision. No such recommendations/decision shall disqualify the Engineer or his nominee or any of the members of the Board, as the case may be, from being called as a witness and giving evidence before the arbitrators or any matter whatsoever relevant to the dispute.
- iii) The reference to arbitration shall proceed notwithstanding that the works shall not then be or be alleged to be complete, provided always that the obligations of the Employer, the Engineer or his nominee and the Contractor shall not be altered by reason of the arbitration being conducted during the progress of the works. Neither party shall be entitled to suspend the works to which the dispute relates, and payment to the Contractor shall be continued to be made as provided by the contract.
- iv) If one of the parties fails to appoint its arbitrators in pursuance of sub-clause [i], within 14 days after receipt of the notice of the appointment of its arbitrator by the other party, then President/Chairman of the nominated Institution shall appoint arbitrator within 14 days of the receipt of the request by the nominated institution. A certified copy of the President's/Chairman's order, making such an appointment shall be furnished to both the parties.
- v) Arbitration proceedings shall be held at Mangalore, and the language of the arbitration proceedings and that of all documents and communications between the parties shall be 'English

- vi) The Arbitration shall be conducted by the experts from the panel of CIDC-SIAC Arbitration Center.
- vii) The decision of the majority of arbitrators shall be final and binding upon both parties. The expenses of the arbitrators as determined by the arbitrators shall be shared equally by the Employer and the Contractor. However, the expenses incurred by each party in connection with the preparation, presentation, etc. of its case prior to, during and after the arbitration proceedings shall be borne by each party itself.
- viii) All arbitration awards shall be in writing and shall state the reasons for the award.
- ix) Performance under the contract shall continue during the arbitration proceedings and payments due to the contractor by the Employer shall not be withheld, unless they are subject matter of the arbitration proceedings.

3.18 BAR CHART:

1. Bar Chart showing stage wise activities of the work should be uploaded **along with the Technical Bid**. However, the successful Bidder shall review the Bar Chart & take prior approval from the Engineer before commencement of work.
2. An update of the Bar Chart shall be a program showing the actual progress achieved on each activity and the effect of the progress achieved on the timing of the remaining work including any changes to the sequence of the activities.
3. The Contractor shall submit to the Engineer on the first day of each week or such longer period as the Engineer may from time to time direct, a progress report in an approved form showing up-to-date total progress, progress achieved against planned progress, during the previous week and progress forecast for the following week for all important items in each section or portion of the Works, in relation with the approved Program.
4. The Contractor shall submit to the Engineer or his nominee, for approval an updated Program at intervals no longer than the period stated in the Contract Data. If the Contractor does not submit an updated Program within this period, the Engineer or his nominee may withhold the amount stated in the Contract Data from the next payment certificate and continue to withhold this amount until the next payment after the date on which the overdue Program has been submitted.
5. The Engineer or his nominee's approval of the Bar Chart shall not alter the Contractor's obligations. The Contractor may revise the Bar Chart and submit it to the Engineer or his nominee again at any time. A revised Bar Chart is to show the effect of Variations and Compensation Events.

3.19 EXTENSION OF INTENDED COMPLETION DATE:

1. The Engineer or his nominee shall extend the Intended Completion Date if a Compensation Event occurs or a Variation is issued which makes it impossible for Completion to be achieved by the Intended Completion Date

without the Contractor taking steps to accelerate the remaining work and which would cause the Contractor to incur additional cost.

2. The Engineer or his nominee shall decide whether and by how much to extend the Intended Completion Date within 21 days of the Contractor asking the Engineer or his nominee for a decision upon the effect of a Compensation Event or Variation and submitting full supporting information. If the Contractor has failed to give early warning of a delay or has failed to cooperate in dealing with a delay, the delay by this failure shall not be considered in assessing the new Intended Completion Date.

3.20 DELAYS ORDERED BY THE ENGINEER OR HIS NOMINEE:

The Engineer or his nominee may instruct the Contractor to delay the start or progress of any activity within the Works.

3.21 MANAGEMENT MEETINGS:

1. Either the Engineer or his nominee or the Contractor may require the other to attend a management meeting. The business of a management meeting shall be to review the plans for remaining work and to deal with matters raised in accordance with the early warning procedure.
2. The Engineer or his nominee shall record the business of management meetings and is to provide copies of his record to those attending the meeting and to the Employer. The responsibility of the parties for actions to be taken is to be decided by the Engineer or his nominee either at the management meeting or after the management meeting and stated in writing to all who attended the meeting.

3.22 EARLY WARNING:

1. The Contractor is to warn the Engineer or his nominee at the earliest opportunity of specific likely future events or circumstances that may adversely affect the quality of the work, increase the Contract Price or delay the execution of works. The Engineer or his nominee may require the Contractor to provide an estimate of the expected effect of the event or circumstance on the Contract Price and Completion Date. The estimate is to be provided by the Contractor as soon as reasonably possible.
2. The Contractor shall cooperate with the Engineer or his nominee in making and considering proposals for how the effect of such an event or circumstance can be avoided or reduced by anyone involved in the work and in carrying out any resulting instruction of the Engineer or his nominee.

B. QUALITY CONTROL:

3.23 IDENTIFY DEFECTS:

The Engineer or his nominee shall check the Contractor's work and notify the Contractor of any Defects that are found. Such checking shall not affect the Contractor's responsibilities. The Engineer or his nominee may instruct the Contractor to search for a Defect and to uncover and test any work that the Engineer or his nominee considers may have a Defect.

3.24 TESTS:

If the Engineer or his nominee instructs the Contractor to carry out a test not specified in the Specification to check whether any work has a Defect and the test shows that it does the Contractor shall pay for the test and any samples. If there is no Defect the test shall be a Compensation Event.

3.25 CORRECTION OF DEFECTS:

1. The Engineer or his nominee shall give notice to the Contractor of any Defects before the end of the Defects Liability Period, which begins at Completion and is defined in the Contract Data. The Defects Liability Period shall be extended for as long as Defects remain to be corrected.
2. Every time notice of a Defect is given, the Contractor shall correct the notified defect within the length of time specified by the Engineer or his nominee's notice.

3.26 UNCORRECTED DEFECTS:

If the Contractor has not corrected a Defect within the time specified in the Engineer or his nominee's notice the Engineer or his nominee will assess the cost of having the Defect corrected, and the Contractor will pay this amount.

C. COST CONTROL:

3.27 BILL OF QUANTITIES:

1. The Bill of Quantities shall contain items for the supply, installation, testing and commissioning work.
2. The Bill of Quantities is used to calculate the Contract Price. The Contractor is paid for the quantity of the work done at the rate in the Bill of Quantities for each item.

3.28 VARIATIONS AND ITS VALUATION:

- i. The Quantities set out in the Bill of Quantities of the tender shall be treated as estimated quantities of the work and shall never be deemed as actual or correct quantities of the works to be executed by the contractor in fulfillment of his obligation under the contract.
- ii. The Engineer shall have the power to order the Contractor in writing to make any variation of the Quantity, quantity or form of the works or any

part thereof that may, in his opinion, be necessary and the Contractor upon receipt of such an order shall act as follows;

- a. Increase or decrease the quantity of any work included in the Contract.
 - b. Omit any work included in the contract.
 - c. Change the routes, position and dimensions of any part of the work.
 - d. Execute extra and additional work of any kind necessary for completion of the works.
- iii. No such variation shall in any way vitiate or invalidate the contract or be treated as revocation of the contract, but the value (if any) of all such variations evaluated in accordance with the Engineer's sole decision shall be taken into account and the contract price shall be varied accordingly.
- iv. Provided variation in the quantity of any work will be permitted which is necessary to complete the works where such increase is not the result of any variation order given under this clause but is the result of the quantities exceeding those stated in the bill of quantities. Provided the variation shall be complied with by the Contractor and the Engineer's subsequent written confirmation of such variation shall be deemed to be an order in writing within the meaning of this clause.
- v. No price escalation is allowed. The rate(s) quoted against the work shall remain firm during the entire contract period. Any change in Forex/rate shall not be considered for price variation.
- vi. The purpose of this document is to define the minimum requirements for the supply, design & engineering, manufacturing, installation, inspection, Commissioning and documentation of all the items and other activities as per BOQ (Bill of Quantities) attached with tender document, for the Job /construction contractor in performing the work of **“Providing illumination for the road near Godown No. 31 / PPP Hospital”**
- vii. The Contractor shall note that all the activities that are required to be performed for completion and successful commissioning of the project needs to be considered in his scope of work. Any missing activities/ supplies in BOQ or in any other project issued documents, but essential for the completion and success full implementation of the project shall be the sole responsibility of the contractor at his cost.
- viii. a. The Contractor shall not be entitled to any claim of extra or additional work unless they have been carried out under the written orders of the Engineer.

b. The Engineer shall solely determine the amount (if any) to be added to or deducted from the sum named in the tender in respect of any extra work done or work omitted by his order.

c. All extra, additional or substituted work done or work omitted by order of the Engineer shall be valued on the basis of the rates and prices set out in the contract, if in the opinion of the Engineer, the same shall be applicable. If the contract does not contain any rates or prices directly applicable to the extra additional or substituted work, then the Engineer may decide the suitable rates on the basis of Schedule of Rates, if any thereon. In all other cases the Engineer shall solely determine suitable rates in the manner deemed by him as fair and reasonable, and his decision shall be final, binding and conclusive.

3.29 PAYMENTS:

Running bills will be paid for at quoted rates for the items in schedule, after acceptance of Bank Guarantee which shall be valid for whole contract period including Guarantee period. Payment will be made within 15 days from the date of receipt of bill, after receipt of items / satisfactory testing & commissioning of system.

Running Account Bill claim shall be submitted separately and corresponding GST for the value of service shall be shown in the tax invoice/ Bill Claim. Following are the stages of Payment;

- a. 70% (Seventy percent) of supplied Item rate against receipt of material at site in good condition and after inspection of the same.
- b. 20% (Twenty Percent) of supplied item rate after completion of Installation, Testing and commissioning etc. and 90 % (Ninety Percent) of payment against items covering only Installation, Testing and commissioning.
- c. 10% (ten percent) will be paid on successful completion of the work and issue of Taking over Certificate in respect of the subject works (totally 100%) after acceptance of Performance Security Deposit (performance Bank Guarantee) for 10% (Ten percent) value of Contract Price to cover guarantee period.
- d. For BOQ items having “Supply and laying/installation/fixing/running/testing/commissioning etc....”, 70% of quoted rate will be considered for supply of items and balance 30% will be considered for laying/installation/fixing/running/ testing/commissioning etc. and payment terms at a, b & c above will be applied accordingly.

Payment along with applicable GST will be released within 15 days subject to recoveries if any, from the date of submission of Tax Invoice after satisfactory completion of work in all respect.

3.30 COMPENSATION EVENTS:

The following mutually agreed Compensation Events unless they are caused by the Contractor would be applicable;

- a. The Employer does not give access to a part of the Site by the Site Possession Date stated in the Contract Data.
- b. The Employer modifies the schedule of other contractors in a way which affects the work of the contractor under the contract.
- c. The Engineer or his nominee orders a delay or does not issue drawings, specifications or instructions required for execution of works on time.
- d. The Engineer or his nominee instructs the Contractor to uncover or to carry out additional tests upon work which is then found to have no Defects.
- e. The Engineer or his nominee gives an instruction for dealing with an unforeseen condition, caused by the Employer, or additional work required for safety or other reasons.
- f. Other contractors, public authorities, utilities or the Employer does not work within the dates and other constraints stated in the Contract that cause delay or extra cost to the Contractor.
- g. Other Compensation Events listed in the Contract Data or mentioned in the contract.

Whenever any compensation event occurs, the Contractor will notify the employer, within 14 days in writing. If a compensation event would prevent the work being completed before the Intended Completion Date, the Intended Completion Date shall be extended. The Engineer or his nominee shall decide whether and by how much the Intended Completion Date shall be extended.

3.31 LIQUIDATED DAMAGES:

- i. In case of delay in completion of the contract, liquidated damages (L.D) may be levied at the rate of 0.5% of the contract price plus applicable GST per week of delay or part thereof subject to a maximum of 10 per cent of the contract price.
- ii. The Employer, if satisfied, that the works can be completed by the contractor within a reasonable time after the specified time for completion, may allow further extension of time at its discretion with or without the levy of L.D. In the event of extension granted being with L.D,

the Employer will be entitled without prejudice to any other right or remedy available in that behalf, to recover from the Contractor as agreed damages equivalent to 0.5% of the contract value plus applicable GST for each week or part thereof subject to the ceiling defined in Clause **3.31(i)**.

- iii. The Employer, if not satisfied that the works can be completed by the contractor, and in the event of failure on the part of the contractor to complete work within further extension of time allowed as aforesaid, shall be entitled, without prejudice to any other right, or remedy available in that behalf, to rescind the contract.
- iv. The Employer, if not satisfied with the progress of the contract and in the event of failure of the contractor to recoup the delays in the mutually agreed time frame, shall be entitled to terminate the contract.
- v. In the event of such termination of the contract as described in clauses **3.31(iii) or 3.31(iv)** or both the Employer shall be entitled to recover L.D. up to ten per cent (10%) of the contract value and forfeit the security deposit made by the Contractor besides getting the work completed by other means at the risk and cost of the Contractor.
- vi. Contractor hereby agree after due assessment of damages that there will be definite loss to the Employer in case of delay in completion of work and the amount of Liquidated damages fixed above is genuine and reasonable to be recovered. Contractor hereby further agrees that Employer is not required to prove the loss suffered to him before recovery of LD.

3.32 OBLIGATIONS OF THE CONTRACTOR:

- i. The Contractor shall exercise all reasonable care and diligence in the discharge of all technical, professional and contractual duties to be performed by them under this Contract within the Time for Completion. The Contractor shall be fully responsible to the NMPA for proper, efficient and effective discharge of their duties.
- ii. The Contractor shall when called upon so to do enter into and execute a Contract agreement as per clause **2.19** of this tender document.
- iii. The successful Tenderer shall furnish bond in the form of Bank Guarantee towards the performance of the work as per clause **2.20** of this tender document.
- iv. If the Board shall consider itself entitled to any claim under the performance Guarantee it shall forth with so inform the Contractor specifying the default of the Contractor upon which he relies. If the Contractor fails to remedy such default within 20 days after the receipt of such notice the Board shall be entitled to forfeit to the extent of the loss or damage incurred by reason of the default.

- v. The Contractor shall proceed with the Works in accordance with the decisions, instructions and orders given by the Engineer in accordance with the condition of the Contract.

3.33 EXECUTION:

The Contractor shall execute and do the works set forth as described in the scope of the work and specifications, including any amendments.

3.34 EXTRAS:

Any extra expenses incurred in connection to the Works by the NMPA in the performance of the Works owing to the neglect or omission on the part of the Contractor in any of the case mentioned in this Contract shall be deducted from any sum due or which may thereafter become due to the Contractor or from any amount lying with them or under their control or he may be called upon to pay the amount of such extra expense to such person or persons as the NMPA may appoint to receive the same and in the event of the Contractor failing to make such payment, the said amount shall be recoverable from him in such manner as the NMPA may determine.

3.35 EXISTING SERVICES: The Contractor shall not store any materials or otherwise occupy any part of the site in a manner likely to hinder the Port operation. Any damage/loss caused by the contractor to the Port property, same shall be rectified at his own cost without any delay with the satisfaction of the Engineer.

3.36 COMPLETION PERIOD:

“Providing illumination for the road near Godown No. 31 / PPP Hospital” shall be completed within **Two (2) months** from the date of execution of Contract Agreement within the stipulated time period specified in Tender.

3.37 INSPECTION & TESTS:

- i. The Employer or his representative shall have right to inspect the work being carried out under this Contract and to test the system to confirm conformity with the specifications. The employer shall notify the Contractor in writing of the identity of a representatives retained for these purposes.
- ii. The tests may be conducted on the premises of the Contractor or its subcontractor (s) at point of delivery and at the final destination. Where conducted on the premises of the Contractor or its subcontractor (s), all reasonable facilities and assistance shall be furnished to the inspector at no discharge to the Employer.
- iii. Should any tested systems fail to conform to the specification, the Employer may reject them, and the Contractor shall make suitable alterations with prior approval of Employer to meet the requirements of the specifications, without any effect on cost of delivery times / project schedules.
- iv. The Employer’s right to inspect, test and where necessary, reject the system shall be in no way limited or waived by reason of the systems having previously been tested and passed by the Employer or its representatives prior to dispatch of the system.

- v. The Contractor shall submit the Quality Assurance plan (QAP), Technical drawings for prior approval before commencement of Inspection / Test at manufacturer's work / Site to the Inspection Agencies / Engineers representatives.

3.38 FINAL ACCEPTANCE:

Upon completion of the work under the Contract a meeting shall be held for the purpose of accepting the system and services. Such meeting shall constitute the Final Acceptance Test under the Contract. In case defects or shortcomings or both which are considered essential, a new meeting shall be convened when the contractor has given notice of completion of the corrective work carried out. Otherwise NMPA may accept the system if the defects or shortcomings or both are not considered essential and the Contractor has agreed to carry out the modifications in conformity with this Contract.

3.39 REJECTION OF DEFECTIVE WORK:

- i. If the complete system at site or any portion thereof before being taken over, is defective, or fail to fulfill the requirements of the Contract, the Engineer shall give notice to the Contractor setting forth particulars of such defects and the Contractor shall forthwith make the defective supply/Installation good or alter the same to make it comply with the requirements of the Contract.
- ii. If Contractor fails to do so within a reasonable time, NMPA may reject and replace the same at the cost of Contractor, the whole, or any portion of the work, as the case may be, which is defective or fails to fulfill the requirements of the Contract. The Contractor's fails and extreme liability under this clause shall be satisfied by the payment to NMPA, the extra cost, if any, of such replacement delivered and erected. Such extra cost being ascertained shall be deducted from the Contractor's bill.
- iii. If any supply of defective items shall have caused delay in the completion of the Contract so as to give rise to a claim for damage on the part of the NMPA under Clause **3.26** of Tender Document nothing contained in this clause shall interfere with or prejudice any rights of the Board of Directors with respect to such claim.

3.40 TAKING OVER CERTIFICATE:

When the whole of the works has been substantially completed and have satisfactorily passed any tests on completion prescribed by the contract, the contractor may give a notice to that effect to the engineer, with a copy to the employer, accompanied by a written undertaking to finish with due expedition any outstanding work during the defects liability period. Such notice and undertaking shall be deemed to be a request by the contractor for the engineer to issue a taking over certificate in respect of the works. The Engineer shall, within 21 days of the date of delivery of such notice, either issue to the contractor, with a copy to the employer, a taking over certificate, stating the date on which, in his opinion, the works were substantially completed in accordance with the contract, or give instruction in writing to the contractor

specifying all the work which in the engineer opinion, is required to be done by the contractor before the issue of such certificate. The Engineer shall also notify the contractor of the any defects in the works affecting substantial completion that may appear after such instructions and before completion of the works specified there in. The contractor shall be entitled to receive such taking over certificate within 21 days of completion, to the satisfaction of the engineer, of the works so specified and remedying any defects so noticed.

3.41 DEFECT LIABILITY PERIOD AFTER TAKING OVER:

- i. In this condition the expression '**Defect liability period**' shall mean a period of **24 months** calculated from the date of Taking Over in accordance with clause **3.40** of Tender Document for **all works**.
- ii. The Contractor shall be responsible for making good with all possible speed at his expense any defect in or damage to any portion of the Works which may appear or occur during the defect liability period without extra cost to NMPA and which arises either;
 - a. From any defective materials, workmanship or Design or
 - b. From any act or omission of the Contractor done or omitted during the said period.
- iii. If any such defects shall appear or damage occur, the Engineer shall forthwith inform the Contractor thereof stating in writing the nature of defect or damage. The provision of this clause shall apply to all replacements or renewals carried out by the Contractor to remedy defects and damage as if the said replacements and renewals had been taken over on the date they were completed to the satisfaction of Engineer but not so as to extend the Defects Liability Period in respect thereof beyond three years from the date of taking over decided by the Engineer as the respective case of remedying may warrant.
- iv. If any such defect or damages were not remedied within a reasonable time, NMPA may proceed to do the work at the Contractor's risk and expense provided that he does so in a reasonable manner.

3.42 INCOME TAX DEDUCTION:

Income Tax as at such rates applicable from time to time will be deducted at source from all running bills and Final Bill and a certificate to this effect will be issued. The deduction of Income Tax can, however, is waived if exemption certificate is produced from Income Tax Authorities. Deduction of income tax at reduced rate can be considered subject to production of valid certificate for the period from Income tax authorities.

The GST applicable shall be shown as a separate line item in the tax invoices, and shall be paid extra. Contractor should provide proper tax invoice as per GST act.

The Tenderer / Contractor shall file the applicable returns with tax departments in time and submit the same as documentary proof.

Contractor shall submit all the GST returns with in time specified. Any ITC lost by NMPA due to non-filing of return will be recovered from the contractor.

3.43 The payment will be made through E-Payment. The Tenderers are required to furnish Bank details for making E-Payment as per the schedule- III of this Tender document.

3.44 MAINTENANCE OF RECORDS/REGISTERS, INSTRUCTION BOOK:

The Instruction Book is to be kept by the Contractor at the site. Any order or instructions issued by the EIC or his authorized representative shall be entered in the book. The Contractor shall sign each entry in token of having seen the same. This shall be returned to the EIC in good condition after the completion of the Contract period.

3.45 NO INTEREST ON ACCOUNT OF DELAYED PAYMENTS:

Any claim for interest will not be entertained by the NMPA with respect to any payment or balance which may be in their hands owing to any disputes between themselves and the Contractor or with respect to any delay on the part of the NMPA in making payment.

3.46 GUARANTEE PERIOD:

- i. The items to be supplied under this Contract shall be guaranteed for a **period of 24 (Twenty Four) months for all works towards satisfactory performance**. The Contractor shall be responsible for any defects that may develop under proper use arising from faulty materials, Designs, workmanship in the work but not otherwise and shall at his own cost remedy such defects when called upon to do so by the Engineer who shall state in writing in what respect any portion is faulty.
- ii. If it becomes necessary for the Contractor to replace or renew any defective portions of the supply of the items under this clause, the provisions of this clause shall apply to the portions of the supply so replaced or renewed until the expiry of 24 months from the date of such replacement or renewal of the abovementioned **period of 24 months**, whichever may be later. If any defects are not remedied within a reasonable time, the Port may proceed to do the work at the Contractors' risk and expenses but without prejudice to any other rights, which the Port may have against the Contractor in respect of such defects.

3.47 EXTENSION OF COMPLETION PERIOD:

If the quantum of total work increases due to additional work against the BOQ for the subject works **“Providing illumination for the road near Godown No. 31 / PPP Hospital”** suitable extension of completion period shall be taken during the approval of additional work from the Competent Authority.

3.48 DEFAULT OF THE CONTRACTOR & TERMINATION:

If the Contractor makes any default or on the happenings of anyone or more of the following events that is to say;

- a. If the Contractor without reasonable cause abandons the Contract or
- b. Suspends the carrying out of the Works for a reasonable time after receiving written notice from the NMPA without any lawful excuse or fails to make proper progress with Works after receiving written notice from the Engineer or
- c. Fails to proceed diligently with the work or
- d. Fails to give the NMPA proper facilities for inspection of the Works of any part thereof for three days after receiving notice in writing by the NMPA demanding the same or
- e. The Contractor has become insolvent or
- f. The Contractor has gone into liquidation or passes the resolution for winding up or
- g. Upon the Contractor making an arrangement with or assignment in favour of his creditor or upon his assigning this contract or
- h. Upon an execution being levied upon the Contractor's good or
- i. Upon winding up order being passed by the court or a Receiver or manager is appointed in respect of any of the property of the Contractor or
- j. Possession is taken by or on behalf of any holder of any debentures secured by floating charges of any of the property of the Contractor or
- k. Fails to complete all or any part of the Works during the time specified for completion of the Contract or such extended time as may be granted by the NMPA.

3.49 TERMINATION OF THE CONTRACT

In the event of repeated instances of unsatisfactory service or any failure at any time on the part of the contractor to comply with the terms and provisions of this contract to the satisfaction of NMPA (who shall be the sole judge and whose decision shall be final, it shall also be open to NMPA to terminate this contract by giving not less than 30 (thirty) days Notice in writing to that effect and if the contractor, does not make good his default within the notice period, NMPA shall be entitled to terminate the contract as a whole or in part.

- i. In the event of such termination of the contract, NMPA shall be entitled to:
 1. forfeit the Performance Guarantee as it may consider fit;
 2. get the balance/remaining work done by making alternative arrangements as deemed necessary and until such time NMPA is able to appoint a new regular Contractor; and recover from the contractor (appointed under this tender) any extra expenditure incurred by NMPA

in getting the work done and damages which NMPA may sustain as a consequence of such action.

- ii. If the extra expenditure incurred by NMPA on account of unsatisfactory performance of the contractor as mentioned in paragraphs above is more than the Security Deposit proposed to be forfeited, the expenditure over and in excess of the Security Deposit may be recovered by deducting the said amount from pending bills of the contractor under this tender or from money due to the contractor by NMPA under this or any other contract or otherwise. The contractor shall have no claim whatsoever against NMPA, in consequence on such recoveries or termination of the contract, as stated above.
- iii. if at any time the contractor becomes insolvent or files an application for insolvency or any creditor of his moves the court for adjudicating him as an insolvent or, if he is convicted by any court of law, withdraws from the contract, NMPA will have the absolute option of terminating the contract forthwith and he shall have no right for damages or compensations on this account.

Further, NMPA reserves the right to terminate/pre-close the contract at its convenience, without assigning reasons to the contractor by giving a notice period of 30 days. The contractor shall not have right of any claim on NMPA on account of such termination.

3.50 DEBARRING OF BUSINESS DEALINGS:

In the event of premature termination of contract in terms of provisions of clause 3.48 above, NMPA shall also be entitled to debar the Contractor for participation in future tenders of NMPA for a period of two (02) years.

Further, in case if it comes to the notice of NMPA that the Bidder/Contractor has used forged documents or misrepresented the facts in any manner either to get the contract or during the pendency of the contract, in such cases NMPA at its sole discretion may disqualify the bid / terminate the contract and debar such Bidder/Contractor for participation in future tenders of NMPA for a period of two (02) years.

3.51 NMPA's LIEN:

The NMPA shall have a lien on and over all or any money that may become due and payable to the Contractor under this Contract or any other Contract or from any amount lying with them or under their control and in respect of any debt or sum that may become due and payable by the NMPA to the Contractor either alone or jointly with another or other and either under this Contract or under any other Contracts or transaction of any nature whatsoever the NMPA and the Contractor.

3.52 FORCE MAJEURE:

If the supply, Commissioning and Testing of equipment/materials is hindered due to force majeure such as war, riots, civil commotion, fire, epidemics, natural calamities, heavy/continuous rain for 8 hrs in a day time during

monsoon such period shall be exempted from **Liquidated Damages** as mentioned in clause **3.31** of this tender document.

3.53 LABOUR LAWS:

The Contractor shall comply with all the provisions of the **Labour Laws and the rules and regulations** made there under as amended from time to time and as applicable from time to time with regard to the employees to be deployed by the Contractor for Electrification, Testing, Commissioning and Maintenance of the system.

3.54 ACTS & STATUTORY RULES:

The contractor shall comply with all the Central State and Municipal laws and rules and shall be solely responsible for complying with the provisions of the contract labour (regulations and abolition) Act 1970 and rules there under and the other enactments that may be applicable including ESI Act, the payment of wages Act, Provident Fund Act, the minimum wages Act, the factories Act, the workmen compensation act or any other applicable legislation and the Municipal by laws or other statutory rules and regulations whatsoever in force in so far as these are applicable. Any obligations finding or otherwise missed under any statutory enactments, rules and regulations there under shall be the responsibility of the contractor and the NMPA will take no responsibility for the same.

- i) The Tenderer must possess documents certifying registration under Employees State Insurance Act, EPF & MP Act and GST.**
- ii) If the Tenderer is not registered under ESI Act and EPF & MP Act for the reasons that he has not employed 10 or more workers as required under said laws, he shall submit an affidavit in this regard that he has never employed 10 or more workers on any given day preceding 12 months from the inception of its operations.**
- iii) The Tenderer to whom ESI Act and EPF & MP Act does not apply, shall mandatorily cover his workers deployed at NMPA site/premises under Employees Compensation Act Policy declaring proper wages.**
- iv) The Tenderer shall submit “Indemnity Bond” as per ANNEXURE-12 for undertaking to indemnify NMPA both loss/legal expenses incurred in case of any claims filed against NMPA by EPFO/ESIC authorities with regard to the workers of the bidder/contractor.**

3.55 SAFETY GEARS:

The Contractor shall at his own expenses provide all safety gears for all labours engaged during the work and failing to do so, the NMPA shall provide

the same and recover the cost there of from any amount due or which may become due to the Contractor or from any amount lying with them or under their control.

3.56 INDEMNIFICATION:

The Contractor shall agree and undertake (**ANNEXURE-11**) to indemnify, keep indemnifies, depended and hold harmless the NMPA and its Officers against all losses, penalties, costs and expenses, duties of any kind whatsoever which may arise on account of breach un-authorized act, fraud deed or any other acts of Contractor or any of its personnel. The Contractor shall also agree and undertake to indemnify and keep indemnifies against any order passed by any executive, quasi-judicial or judicial authority wherein the NMPA is compelled to obey the order which arise due to breach of contract by the Contractor.

The Contractor shall indemnify, protect and defend at its own cost, New Mangalore Port Authority and its agents & employees from & against any/all actions, claims, losses or damages arising out of;

- i. Any violation by the Contractor in course of its execution of the contract of any legal provisions or any right of third parties.
- ii. Contractor's failure to exercise the skill and care required for satisfactory execution of the contract.
- iii. The Contractor shall indemnify NMPA against all claims for compensation by or on behalf of any workman employed by him in connection with the contract, for injury or death by accident under the Workman Compensation Act (Act VIII of 1923) as amended from time to time.
- iv. The Contractor shall be responsible for all commissions and omissions on part of manpower engaged for the purpose. NMPA shall not be responsible in any manner whatsoever, in matters of injury/death/health etc. of the Contractor's employees performing duties under the contract.

4. SPECIAL CONDITIONS OF CONTRACT

- 4.1 The rates quoted shall be Firm and inclusive of all cost & Duties and exclusive of applicable GST. The Employer shall not provide any concessional “C” or “D” Form.
- 4.2 The Contractor should have **valid Electrical Contract License, ESI, PF & GST**- all in the same name (Bidder’s name) and same should be uploaded along with the Technical Bid.
- 4.3 The Contractor shall carryout the work as a complete job i.e. Supply materials, their storage, keeping under safe custody, transporting to work site, fixing, testing and commissioning of the whole work. The Tenderers should satisfy themselves about the quantities indicated in the Schedule and it is the responsibility of the supplier to supply and make the system operational to the satisfaction of Engineer.
- 4.4 The supply items should have Test Certificates/warranty certificates and the same shall be submitted along with supply of materials.
- 4.5 Delay in making the execution site available to the Contractor will not form a cause for any claims. The Port Authority will inform the Contractor of such possible delay in advance and a suitable extension of time for completion shall be considered.
- 4.6 The Successful Contractor shall take approval from the Engineer in charge for technical datasheets, drawings etc. before procurement of material / fabrication of materials etc. and should supply all materials/equipments as per relevant standard & Tender specifications and carryout the complete work including Testing and commissioning as per applicable act.
- 4.7 Any part or whole of the system, which requires the approval of the statutory body, if any, should be arranged by the Contractor at his cost. It is the responsibility of the Contractor to submit the system drawings with all details to the statutory body and obtain their approval, if any.
- 4.8 All related Civil works shall be responsibility of the Contractor. The Contractor should take timely action to complete all civil works in all respects.
- 4.9 Power supply, if available, will be given to the Contractor **on free of cost**. Wherever such source is not available, the contractor has to make his own arrangements. Tapping of power from the source point of NMPA to the required location will have to be arranged by the Contractor at his cost conforming to IE Rules / Standards.
- 4.10 The Contractor has to make his own arrangement for engaging all tools & tackles, testing equipment’s etc.

- 4.11 The Equipment shall be insured in the name of Employer for 110% of Ex-works cost from the place of dispatch to the place of destination & till handing over / taking over of the Equipment to the satisfaction of the Employer.
- 4.12 The Contractor has to make his own arrangements for construction of temporary stores; office work sheds etc., for their requirements at his own cost. Land for such temporary work sheds, stores, site office etc., till the work is completed will be given free of rent at spot approved by NMPA. The sheds shall be constructed with non-inflammable materials like G.I. sheets etc., and shall be removed in reasonable time after the work is completed. In case the Contractor fails to remove the same, the Department will remove the same and the cost of such removal will be recovered from any amount due from the Contractor.
- 4.13 **Site Register** is to be maintained by the Site Engineer (AE/AEE/EE) at site on daily basis with details of works carried out on that particular day, defects noticed by the Site Engineer (AE/AEE/EE) and instructions given to the Contractor etc. Any orders or instructions issued by the Engineer-in-Charge or Higher Authorities shall be entered in the book and shall be deemed to have been legally issued.
- 4.14 **Hindrance Register** is to be maintained by the Site Engineer (AE/AEE/EE) at site & should contain all the Hindrances to the work due to the reasons attributed either to the Contractor or Port date wise and date of resumption of work. The Contractor and Engineer in charge should sign each entry in token of having seen the same.
- 4.15 The Contractor is responsible for taking precautionary measures for the safety of the lives of the workmen working under him and the responsibility arising due to any mishap during the execution of work, the payment of any compensation etc., lies entirely on the part of the Contractor. Safety nets, life jackets, Helmets required while working in site and Danger Boards, barricades are to be provided by the Contractor without any extra cost to the Port Authority.
- 4.16 The Contractor should ensure, that all necessary arrangements for the safety of others and also his men and materials while performing the work, are well maintained at his cost, risk and responsibility. He should ensure proper watch of the signals by providing barricades, lights, vigils, precautionary measures etc., to ensure safety at his work.
- 4.17 The Port working hour is from 8.00 A.M. to 1.00 noon and from 2.00 P.M. to 5.00 P.M. If any work is carried out by the Contractor requiring supervision beyond Port working hours, the Contractor shall apply in writing well in advance of such work to the Engineer to arrange for such supervision.
- 4.18 All rules and regulations governing the New Mangalore Port Authority shall be applicable.

- 4.19 The site for the work will be handed over to the Contractor in phases for the execution as soon as the work order is given. In case the entire site is not handed over to the Contractor, he should programme his work in such a way so as not to hamper the progress in any way and a suitable extension of time shall be considered.
- 4.20 Any damages caused to the Port property either directly or indirectly shall be made good by the Contractor at his own cost.
- 4.21 The Tenderer(s) shall be required to quote his / their rates in figures as well as in words without any correction(s). If there is any correction(s) in the tender, such corrections should be attested by the Tenderer(s) before submission of the tender. However, the rates shall be quoted in words and figures, in case of dispute, rates in words shall be taken as final.
- 4.22 Port entry passes to the Contractor and his workmen and vehicle during the period of work will be issued on a **chargeable basis to carry out the work as per rules.**
- 4.23 **Completion Drawing & Documentation:**
On the basis of drawings issued and additional drawings generated during the course of execution of works & documentation required for various components and sub-components, the Contractor should prepare completion documents generally as below but not limited to;
- a. Supply items - The contractor shall furnish one set of original manuals, leaflets etc. All drawings and documents are to be neatly filed in a heavy duty binder and indexed.
 - b. Copy of all the Test reports and Guarantee/Warranty certificates are to be presented separately in a folder for records and reference.
- 4.24 The successful Bidder / Contractor shall furnish an undertaking on their Firm's letterhead for the following before executing the Contract agreement;
- a. We will ensure that our workforce will be provided with and use all necessary safety gears and equipments required for the job.
 - b. We will follow all the required safety procedures while executing the job.
 - c. We indemnify the Port for any accidents / incidents while carrying out the Contract.
- 4.25 The Department's Standard Operating Procedure (SOP) will be shared with the successful Bidder / Contractor at the time of signing of agreement. The successful Bidder / Contractor have to give an undertaking for complying with the same. In case if the successful Bidder / Contractor does have a defined SOP for carrying out the tendered work, the same shall be submitted to the Executive Engineer (E) for scrutiny and approval for its applicability before commencement of the work.

4.26 **Addition/Alteration:**

The Contractor shall not be entitled to any claim of extra or additional work unless they have been carried out under the written orders of the Engineer in charge.

4.27 **Others:**

- 1) Accommodation for the deployed staff shall be arranged by the Contractor at his own cost; however the Port quarters may be allotted on chargeable basis if available as per applicable rules of NMPA.
- 2) At the end of the period of contract, all the equipment under this tender shall be handed over to the Port on as is where basis is in good working condition.
- 3) The hardware, software and all related licenses thereto shall be under the ownership of the Port. The bidder shall obtain/issue licenses or such other certification/documentation required for the purpose in the name of the NEW MANGALORE PORT AUTHORITY.
- 4) The successful Bidder shall be responsible for insurance of all the manpower & hardware/network supplied and installed by vendor for risk coverage including accidental hazards, death & disability of person, material breakage due to negligence, theft, storm, fire or any other hazards which may occur due to trespassing of vehicles & /or natural adverse climatic conditions and calamities - War, Fire, Cyclone, salinity problems at shore etc.

5. SCOPE OF WORK & TECHNICAL SPECIFICATIONS

5.1 SCOPE

The proposed work is to provide illumination for the road near Godown No. 31 / PPP Hospital of New Mangalore Port Authority, Panambur, Mangalore. The work involves Supply, Installation, Testing and Commissioning of 1 No. High Mast with LED flood lights, High Mast control panel, RCC barricade wall and foundation for the High Mast, Octagonal Poles with street lights, LT UG cable etc.

5.2 TECHNICAL SPECIFICATIONS OF HIGH MAST - 20 Mtr:

APPLICABLE STANDARDS:

The following shall be the Reference Standards for the loading of the High mast:

<u>Code No.</u>	<u>Title</u>
a). I.S.875 (Part III) 1987.	Code and practice for design loads for Structures.
b). BSEN 10025.	Grades of MS. Plates.
c). BS.ISO 1461.	Galvanising.
d). TR. No.7 2000 of ILE, UK.	Specification for Mast and foundation.

5.2.1 **Structure:**

The High mast shall be of continuously tapered, polygonal cross section, at least 20 sided, presenting a good and pleasing appearance and shall be based on proven In-Tension design conforming to the standards referred to above, to give an assured performance, and reliable service. The structure shall be suitable for wind loadings as per IS 875 part3 1987.

5.2.2 **Construction:**

The mast shall be manufactured using special steel plates, conforming to BS-EN10-025/DIN 17100/BS 4360 or equivalent and shall be delivered in multiple sections of effective length 10 metres. Thus a **20 M** mast shall be delivered in 2 sections. At site the sections shall be joined together by slip-stressed-fit method. No site welding or bolted joint shall be done on the mast. The minimum overlap distance shall be 1.5 times the diameter at penetration.

The mast shall be provided with fully penetrated flange, which shall be free from any lamination or incursion. The welded connection of the base flange shall be fully developed to the strength of the entire section. The base flange shall be provided with supplementary gussets between the bolt-holes to ensure elimination of helical stress concentration. For the environmental protection of the mast, the entire fabricated mast shall be hot dip galvanised, internally and externally, having a uniform average thickness of 86 microns to 65 micron as per BSEN-1461/BS ISO1461/IS/2629-1966. Galvanising shall be done in single dipping method for better adhesion and life.

5.2.3 **Door Opening :**

An adequate door opening shall be provided at the base of the mast and the opening shall be such that it permits clear access to equipment like winches, cables, plug and socket, etc. and also facilitate easy removal of the winch. The door opening shall be complete with a close fitting, vandal resistant, weatherproof door, provided with a heavy-duty double internal lock with special paddle key.

The door opening shall be carefully designed and reinforced with welded steel section, so that the mast section at the base shall be unaffected and undue buckling of the cut portion is prevented.

Size of door opening shall well suitable to avoid buckling of the mast section under heavy wind conditions.

5.2.4 **Dynamic Loading for the Mast:**

The mast structure shall be suitable to sustain an assumed maximum reaction arising from a wind speed as per IS 875. The design life of the mast shall be 25 years.

5.2.5 **Lantern Carriage:** with 8 arms

5.2.5.1 **Fabrication:**

A fabricated Lantern Carriage shall be provided for fixing and holding the **10 Nos. 500 W** LED flood light fittings and control gear boxes and also have a perfect self balance. The Lantern Carriage shall be fabricated in two halves and joined by bolted flanges with stainless steel bolts and nuts to enable easy installation or removal from the erected mast. The inner lining of the carriage shall be provided with protective PVC arrangement, so that no damage is caused to the surface of the mast during the raising and lowering operation of the carriage. The entire Lantern Carriage shall be **hot dip galvanised** after fabrication.

5.2.5.2 **Junction Box.**

Weather proof junction box, **IP 55** made of Cast Aluminium shall be provided on the Carriage Assembly as required, from which the inter-connections to the designed number of the flood light luminaires and associated control gears fixed on the carriage, shall be made.

5.2.6 **Raising and lowering mechanism:**

For the installation and maintenance of the luminaires and lamps, it will be necessary to lower and raise the Lantern Carriage Assembly. To enable this, a suitable Winch Arrangement shall be provided, with the winch fixed at the base of the mast and the specially designed head frame assembly at the top.

5.2.6.1 **Winch: Double drum with double gears type**

The winch shall be of completely self sustaining type, without the need for brake shoe, springs or clutches. Each driving spindle of winch shall be positively locked when not in use, by gravity activated PAWLS. The capacity, operating speed, safe working load, recommended lubrication and serial number of the winch shall be clearly marked on each winch.

The gear ratio of the winch shall be 53:1. However the minimum working load shall not be less than 750 Kg. The winch shall be self-lubricating type by means of an oil bath and the oil shall be readily available grades of reputed producers.

The winch shall have double drum having grooves to ensure perfect seating suitable and tight rope lay with no chances of rope slippage. The rope termination in the winch shall be such that distortion or twisting is eliminated and at least 5 to 6 turns of wire ropes remain on the drum when the lantern carriage is fully lowered and rested on the pads. It should be possible to operate the winch manually by a suitable handle and by an integral power tool. Operation of the winch with manual handle shall be independent of the power tool. Winches with manual operation through the power tool shaft shall not be accepted. Individual drum operation of the winch shall be possible. A double drum winch shall have two drums and two worm gears independent in operation for increased safety. It shall be possible to remove the double drum after dismantling through the door opening provided at the base of the mast. Also a winch gear box for simultaneous and reversible operation of double drum winch shall be provided. Manufacturer Test certificates shall be submitted along with the winch.

5.2.7 **Head Frame: (with top canopy)**

The head frame which is to be designed as a capping unit of the mast, shall be of welded steel construction, galvanised both internally and externally after assembly. The top pulley shall be of

appropriate diameter, large enough to accommodate the stainless steel wire ropes and the multi-core electric cable. The pulley block shall be made of non-corrodable material, and shall be of die cast Aluminium Alloy (LM-6). Pulley made of synthetic materials such as Plastic or PVC are not acceptable. Self-lubricating bearings and stainless steel shaft shall be provided to facilitate smooth and maintenance free operation for a long period. The pulley assembly shall be fully protected by a canopy galvanised internally and externally.

Close fitting guides and sleeves shall be provided to ensure that the ropes and cables do not dislodge from their respective positions in the grooves. The head frame shall be provided with guides and stops with PVC buffer for docking the lantern carriage.

5.2.7.1 **Stainless Steel Wire Ropes** :

The suspension system shall essentially be without any intermediate joint and shall consist of only non-corrodable stainless steel of AISI 316 grade or better grade.

The stainless steel wire ropes shall be of 7/19 construction, the central core being of the same material. The overall diameter of the rope shall not be less than 6 mm. The breaking load of each rope shall not be less than 2350 kg. giving a factor of safety of over 5 for the system at full load. The end constructions of ropes to the winch drum shall be fitted with talurit. The thimbles shall be secured on ropes by compression splices. Two continuous lengths of stainless steel wire ropes shall be used in the system and no intermediate joints are acceptable in view of the required safety. **No intermediate joints/terminations, either bolted or else, shall be provided on the wire ropes between winch and lantern carriage.** Manufacturer certificate for the rope to be produced.

5.2.8 **Electrical System, Cable and Cable Connections** :

A suitable terminal box shall be provided as part of the contract at the base compartment of the high mast for terminating the incoming cable. The electrical connections from the bottom to the top shall be made by special **trailing cable**. The cable shall be EPR insulated and PCP sheathed to get flexibility and endurance with **Rodent proof coating**. Size of the cable shall be minimum 5 core 4 sq mm copper. The cable shall be of reputed make. At the top there shall be weather proof junction box to terminate the trailing cable. Connections from the top junction box to the individual luminaires shall be made by using 3 core 2.5 sq. mm flexible PVC copper cables of reputed make. The system shall have in-built facilities for testing the luminaries while in lowered position.

Also, suitable provision shall be made at the base compartment of the mast to facilitate the operation of internally mounted, electrically operated power tool for raising and lowering of the lantern carriage assembly. The trailing cables of the lantern carriage rings shall be terminated by means of specially designed, metal clad, multipin plug and socket provided in the base compartment to enable easy disconnection when required. The costs of copper cable, cable connections, terminations must be included in the High mast quoted price itself and no separate item/quantity is considered.

5.2.9 **Power Tool for the Winch**:

A suitable, high-powered, electrically driven, internally mounted power tool, with manual over ride shall be supplied for the raising and lowering of the lantern carriage for maintenance purposes. The speed of the power tool shall be to suit the system. The power tool shall be single speed, provided with a motor of the required rating. The power tool shall be supplied complete with suitable control. The capacity and speed of the electric motor used in the power tool shall be suitable for the lifting of the design load installed on the lantern carriage.

The power tool mounting shall be so designed that it will be not only self supporting but also aligns the power tool perfectly with respect to the winch spindle during the operations. Also, a handle for the manual operation of the winches in case of problems with the electrically operated tool, shall be provided and shall incorporate a torque limiting device. The power tool operation shall always be through a separate torque-limiting device to protect the wire ropes from over stretching. It shall

be mechanical with suitable load adjusting device. The torque limiter shall trip the load when it exceeds the adjusted limits. There shall be suitable provision for warning the operator once the load is tripped off. The torque limiter is a requirement as per the relevant standards in view of the overall safety of the system. Each mast shall have its own power tool motor.

5.2.10 **Lightning Finial**

One number heavy duty hot dip galvanised lighting finial shall be provided for each mast. The lightning finial shall be minimum 1.2 M in length and shall be provided at the centre of the head frame. It shall be bolted solidly to the head frame to get a direct conducting path to the earth through the mast. **The lightning finial shall not be provided on the lantern carriage under any circumstances in view of safety of the system.**

5.2.11 **Aviation Obstruction Lights:**

Suitable Aviation Obstruction Lights of reliable design and reputed manufacturer shall be provided on top of each mast. The aviation fitting shall be Heavy duty & weather proof and yellow painted suitable for housing two nos. LED lamps equivalent to 100 W GLS lamp. The Omni directional red colour light shall be prewired up to the terminal block. The unbreakable red coloured polycarbonate dome shall be provided and secured to housing by 3 nos. screws. The Aviation obstruction light shall be Degree of protection: IP 43 and Electrical safety-Class-I. Threaded stem with lock nuts for mounting on the pipe above the high mast structure to be provided.

5.2.12 **Earthing Terminals:**

Suitable earth terminal using 12 mm diameter stainless steel bolts shall be provided at a convenient location on the base of the Mast, for lightning and electrical earthing of the mast.

5.2.13 **Control Panel**

Supply of stainless steel grade **SS 304** control panel of size **600(W) x 760(H) x 210(D)**mm with Rain canopy, single door type(Right side door hinge) with cam lock door sealing Gasket and Gland plate with required openings etc., complete. Material: Enclosure thickness- 2.0 mm, Door – 2.0mm & Mounting plate – 2.5mm comprising the following components with control wiring with 10 Sq.mm copper wire and 2.5 Sq.mm copper wire for motor circuit and termination with suitable lugs. Work including supply & fixing of the components as per BOQ.

- i) 1 No. 63A, 4P, 25KA MCCB
- ii) 3 Nos. 32A, SP, MCB for high Mast light control
- iii) 1 No. 16A , 3 pole MCB for Motor Control
- iv) 4 Nos., 100 A ,CBT connector for incomer
 - v) 50 Amps CBT Connectors - 4 Nos.
 - vi) 16 Amps Connectors - 4 Nos.
 - vii) 1 No. MNX 45, 3P, Contactor with add on block
 - viii) 1 No. 24Hrs Timer
 - ix) 1 No. Auto Manual selector switch to bypass timer
 - x) Forward and Reverse Contactor with push button control to raise/lower the lantern carriage for “fixed 3 phase, 415V Winch Electric Motor of suitable rating” as per the recommendations of manufacturer.

5.2.14 **Incoming Power Cable**

A cable of size 4 x 25 sq.mm Aluminium conductor, Armoured cable for power supply and 4 x 2.5 sq.mm Copper conductor Armoured cable for motor supply shall be provided from control panel to the base compartment of the high mast. Cable shall be taken to the base compartment of the high mast through the provision made in the foundation. The incoming power cable for lighting and motor from control panel to the base compartment of the high mast shall be included in the High mast price and no separate item/qty. is considered.

5.2.15 **Civil Foundation:**

The High Mast Towers along with base plate shall be erected on the concrete foundation as per firms design approved by New Mangalore Port Authority. The firms shall furnish necessary civil foundation drawing for approval based on the **soil bearing capacity Test results**. The foundation shall be designed to meet the soil conditions. The foundation provided shall have adequate bolts of adequate diameter and height for anchoring the base plate of the mast. The contractor shall ensure correct vertical and horizontal alignment of the foundation bolts while carryout the foundation works by using suitable steel template. Necessary power supply point required for erecting towers will be provided by NMPA at free of cost for the above construction work for curing and erection works at nearest possible point. Contractor has to make his own arrangements for conveying the water to the foundation site.

Note:

The Tenderer shall inspect the site and get acquainted with the nature of civil foundation that is required for erecting the High Mast before offering their Tender.

5.2.16 **RCC barricade wall around the high mast**

Design & construction of RCC barricade wall around the high mast by using M 20 concrete with 10 mm vertical rod at a gap of 200 mm double layer and 3rows of 8 mm horizontal rod by keeping 2000 mm inner radius from centre of high mast foundation

Earth work excavation in hard soil: - 4.2x0.7x0.65 m (LXBXD) =6 CuM

Providing laying PCC 1:3:6 using 20 mm granite metal: 4.2x0.7x0.15 m (LXBXD) =1.39 CuM

Providing laying RCC 1:1.5:3 using 20 mm granite metal: (raft footing) 4.2x0.5x0.2 m (LXBXD) =1.32 CuM

Providing laying RCC 1:1.5:3 using 20 mm granite metal: (side wall) 4.2x0.2x1.05 m (LXBXD) =2.77 CuM

Providing TMT steel main bars 10mm dia @ 200 c/c double layer----132.58 kgs

Providing TMT steel main bars 10mm dia @ 200 c/c raft top----28.64 kgs

Providing TMT steel distribution bars 8mm dia 4 rows----44.29 kgs

Providing 20mm thick cement plaster in single coat with cement mortar 1:3 inside,outside, top: 29.03 sqmm

5.3 TECHNICAL SPECIFICATIONS OF 500W LED FLOOD LIGHT FITTINGS:-

500W LED FLOOD LIGHT FITTINGS suitable for 20M High mast applications.

500 W LED Flood light fittings has to comply the following Requirement

- 1) Rated voltage: 230 V AC, 50 HZ. Operating voltage: 120-277 V AC
- 2) System wattage: 500 W
- 3) P.F: >=0.95
- 4) Luminaire efficacy: 120 lm/W or more
- 5) CCT & CRI :- 5000K & >70
- 6) Driver efficiency:>85%

- 7) Total lumens: >=60000(system efficiency)
- 8) Protection: O.C, SC, Surge protection of min 10 KV , SPD
- 9) Mounting: bracket
- 10) Main housing/ heat shrinks material: Aluminum extruded/ Aluminum PDC
- 11) Housing end caps & CG box: aluminum PDC
- 12) Front cover: clear toughened glass
- 13) LED lumens maintenance: 50000 hrs @L70
- 14) Control gear: isolated, electronic, CC drive
- 15) Hardware: SS
- 16) IP:66
- 17) Impact resistance: IK08
- 18) Name of the make: shall be engraved/embossed/printed on light fitting
- 19) Fitting shall have NABL certification

*** LM 79 & LM 80 Certificate to be produced during execution of work.**

*** LED fittings shall have 2 years Guarantee.**

5.4 TECHNICAL SPECIFICATIONS OF 9Mtr OCTAGONAL POLE:

i. Octagonal pole: 9 Mtrs height, hot dip Galvanized, Top 70mm and bottom 155mm diameter, base plate 260x260x16mm, PCD 250 and foundation bolts M24x750mm with suitable single arm bracket of 1500mm, 40/50mm dia.

9 Mtrs long hot dip Galvanized, Octagonal Street light poles with BSEN 10025 GRADE S355JO steel plate for shaft, IS 2062 for base plate with door opening arrangements , including suitable boards, Bakelite sheet and MCB's as per IS specifications suitable to withstand the wind speed of 47 m/s for 9 Mtr Pole in single section and single joint welded as per IS 9595/IS10178AWS having dimensions bottom 155mm dia , top 70mm dia with 3mm thick suitable base plate 260X260X16mm, PCD 250 and foundation bolts M24X750mm long 4 nos " J" type along with template and the Pole shall be hot dip galvanized in single dipping with not less than 65micron as per ASTM-A123 and153 etc.

a. FOUNDATION FOR OCTAGONAL POLE:- Foundation for 9 Mtrs Octagonal GI Pole shall be carried out as per the manufacturer's drawings and recommendation & approved by the Department.

b. BRACKET OF OCTAGONAL POLE: Supplying and fixing Single arm bracket 1500mm long made up of GI of suitable dia along with suitable GI clamps, bolts, nuts etc. complete to 9 Mtrs Octagonal pole. All the hardware shall be GI/stainless steel only.

5.3 TECHNICAL SPECIFICATIONS OF 150W LED STREET LIGHT FITTINGS:-

150W LED streetlight luminaire with pressure are cast aluminium housing body for optimal thermal dissipation. Lamp compartment comprising of anti-glare clear diffuser with Injection moulded polycarbonate material, delivering superior light output rated life Burning Hrs. 5000hr @Lumen Maintenance of 70%,maximum light intensity should be between 60 degree to 70degree.CCT>5500k,IP66 optical and electrical compartment & impact resistance of complete luminaire>1K08. Power factor>0.9 with mains, Surge Protection -Min 5KV along with Over voltage /Overload/Short circuit/miss-wiring protection. Compatible for pole mounting with outer dia of 40mm to50mm.Universal Voltage driver to operate wide voltage range from 100V to 270V 50/60Hz application. Compliance to IS 10322/IEC 60598, LM 79 & LM 80 Adherence with RoHS. UL approved MCPCB. Top access street light with single screw to ensure ease of maintenance at the sight site location minimized minimal tools. LED Light fixture with 150W System power consumption. LED Efficiency>130lm/w, nominal CRI>75. Luminaire manufacture should have accredited by NABL/CPRI & any Government certified agency & Design & Development facility certified ISO 9001:2008. Housing with Supplier word mark/name shall be Engraved/Embossing on the die cast housing/Body part. Warranty of 2 years against any manufacturing defect.

*** LM 79 & LM 80 Certificate to be produced during execution of work.**

*** LED fittings shall have 2 years Guarantee.**

5.4 TECHNICAL SPECIFICATIONS OF LT CABLE:-

Data sheet for LV cables

5.4.1 Scope

Supply, laying, testing, commissioning and making terminations of 1.1 kV grade XLPE insulated, PVC extruded inner sheathed armoured Cables.

5.4.2 Codes & Standards

The design, construction, manufacture and performance of cables shall comply with all currently applicable statutes, regulations and safety codes of the locality where cables shall be installed. Nothing in this specification shall be construed to relieve the successful Bidder of his responsibility.

Unless otherwise specified, the cables shall conform to the latest applicable IS/IEC standards.

s.no	Description	Remarks
	Voltage Rating	1,1KV grade
	Working Voltage	415V TPN system
	Frequency	50Hz
	Type of Earthing	Solidly Grounded
	No. of Cores / Size Required	3.5 C x 25 Sq.mm 3.5 C x 50 Sq.mm

	Core Colours	Red-Yellow-Blue for Phase and Black for Neutral
	Conductor Material	Stranded Aluminium, IS 8130/1984 with latest amendments
	Type of Insulation	XLPE
	<i>Laying of core</i>	<i>Right hand lay for outer most layer cables, successive layers in opposite layers</i>
	<i>Inner sheath thickness</i>	<i>As per IS: 7098 (Part-I)</i>
	<i>Armouring</i>	Galvanised steel wire / Taped
	<i>Outer sheath type</i>	<i>As per IS: 5831- 1984 with latest amendments</i>
	Embossing of cable make, Size of cables, Running length in meters	Required as per relevant IS
	Type Test Certificate	Required as per IS
	Routine Test Certificate	Required as per IS
	Acceptance Test	Required

Note : The cable to be embossed the length on every running meter and on each meter length on the outer sheath, year of Manufacture conforming to IS: 7098(Part-I)

5.4.3 Packing and Markings :-

The cable shall be wound on a drum conforming to IS:10418-1982 and packed. The ends of the cable shall be sealed by means of non-hygroscopic sealing material.

The cable drum shall carry the following information stenciled on the drum:

Manufacturer's Name and Trademark

- i) Type of Cable and Voltage Grade
- ii) Number of Cores
- iii) Nominal cross-sectional area of conductor
- iv) Cable code
- v) Length of Cable on drum
- vi) No. of lengths on the drum if more than one
- vii) Direction of rotation of Drum
- viii) Gross weight
- ix) Weight of Drum with Battens (if any)
- x) Weight of cable
- xi) Reference of any Indian Standard,
- xii) ISI Mark

5.4.4 Cable Laying and Handling:

The cable shall be laid directly in ground on bedding free from large stones, pieces of rocks, etc. and drawn in Hume pipes or ducts wherever necessary. Cables shall be laid carefully to avoid any damage. It should be ensured that both ends of the cable are properly sealed to prevent absorption of moisture during transportation, storage, etc. Sufficient number of sealing caps shall be available at site to ensure sealing of cable ends in case of part use of drum. When cable drums have to be moved over short distances, they should be rolled in the direction of the arrow, marked on the drum. While removing cables the drums shall be properly mounted on jacks or on a cable wheel. The Tenderer should

store the cable drums at site on hard packed surface, protect from the sun and rain, duly allowing free circulation of air. Where gradients and changes in depths are unavoidable, they shall be gradual. The bottom of the trench shall be level and free from stone, brick bats etc. The LT cable shall be laid on existing trench, Drain, Duct, GI pipe, On wall, Hume pipe and Structure as required. If during laying of cables, if any pavor blocks are removed it shall be refixed as original condition. Any minor civil work during laying of cables will be carried out by the contractor as required.

5.5 RCC barricade wall around the high mast

Design & construction of RCC barricade wall around the high mast by using M 20 concrete with 10 mm vertical rod at a gap of 200 mm double layer and 3rows of 8 mm horizontal rod by keeping 2000 mm inner radius from centre of high mast foundation

Earth work excavation in hard soil: - 4.2x0.7x0.65 m (LXBXD) =6 CuM

Providing laying PCC 1:3:6 using 20 mm granite metal: 4.2x0.7x0.15 m (LXBXD) =1.39 CuM

Providing laying RCC 1:1.5:3 using 20 mm granite metal: (raft footing) 4.2x0.5x0.2 m (LXBXD) =1.32 CuM

Providing laying RCC 1:1.5:3 using 20 mm granite metal: (side wall) 4.2x0.2x1.05 m (LXBXD) =2.77 CuM

Providing TMT steel main bars 10mm dia @ 200 c/c double layer----132.58 kgs

Providing TMT steel main bars 10mm dia @ 200 c/c raft top----28.64 kgs

Providing TMT steel distribution bars 8mm dia 4 rows----44.29 kgs

Providing 20mm thick cement plaster in single coat with cement mortar 1:3 inside,outside, top: 29.03 sqmm

5.6 ALLIED ELECTRICAL WORKS :

- a) All allied Electrical works as per the Bill of Quantities to be carried out complete the work in all respects.
- b) The materials required / intended for the work should be handled carefully and neatly installed / laid / commissioned and any damages during installation will be Contractors account and same shall be rectified immediately to its original condition.
- c) The Miscellaneous works to be carried out invariably whether clearly mentioned or not in the specifications and BOQ and to be completed in all respects the said project work.

5.7 GENERAL NOTES:

All the drawings of Design, Construction, Foundation Details, catalogues/Brochures of High Mast and cable layout drawings, type Test certificates, routine Test certificates etc. should be submitted by the contractor in THREE sets invariably mentioned or not in the Tender Schedule. As Built drawings in THREE sets to be submitted, after the completion of work,.

All the drawings to be got approved by the Engineer –in –charge before Fabrication, Assembly, installation etc.

All the works of installation, laying of of cables, testing commissioning to be carried out in the presence of Engineer-in-charge.

All the Hardware materials/Miscellaneous materials should be galvanized and conform to IS and Specification and got approved by the Engineer – in-charge before installation and commissioning.

The High Mast, lighting fixtures, cables etc. to be supplied for the work should conform to Applicable Standards as per Technical specifications of Tender Document. Routine Test certificate of High Mast shall be furnished. Other items are inspected at site as per the requirement. The contractor should provide all facilities to test the materials at site

The total turn-key project should be guaranteed for a period of 24 months from the last date of commissioning for all the materials and work carried out by the contractor. In the event of failure during the Guarantee Period, the restoration work shall be done free of cost by the Contractor within 24 Hours of giving notice or else, the expenditure incurred by NMPA to carry-out the defective work will be recovered from the performance guarantee amount with the NMPA.

PARTICULARS OF BIDDER

All individual firms or each of the partners of an organization submitting the tender must complete the information in this form.

1.	Full name of the Firm:	
2.	Head Office address:	
3.	Contact person name at Head office:	
4.	Telephone number/s:	
5.	Fax number/s:	
6.	E-mail Id	
7.	Branch Office address if any:	
8.	Contact person name at Branch office:	
9.	Telephone number/s:	
10.	Fax number/s:	
11.	E-mail Id	
12.	Works address:	
13.	Contact person name at Works:	
14.	Telephone number/s:	
15.	Fax number/s:	
16.	E-mail Id	
17.	Place of Registration/ Incorporation:	
18.	Year of Registration/ Incorporation	

Signature & seal of the Bidder

TENDER FORM

(Note: - Bidders are required to fill up all the blank spaces in this Tender Form)

To,

**The Chief Mechanical Engineer,
New Mangalore Port Authority,
Panambur, Mangalore – 575 010.
India.**

1. Having examined the Instructions to Bidders, Conditions of Contract, Specifications and Schedules attached to the Tender with Annexure and having satisfied ourselves of the site conditions for the Tender for **“Providing illumination for the road near Godown No. 31 / PPP Hospital”** we the undersigned, offer to execute the Contract as per conditions of contract, at rates for items of work in the Schedule of items of work and rates attached herewith.
2. We further undertake, if our tender is accepted, to deposit within 21 days from the date of receipt of the letter of acceptance, Bank Guarantees to the extent of **10% (Ten percent)** of the contract price in the manner set forth in the GCC of tender.
3. We further undertake, if our tender is accepted, to enter into and execute within 14 days of our being called upon to do so, an Agreement in the form annexed and the conditions of contract with such modifications as are agreed upon.
4. Unless and until a formal agreement is prepared and executed, this tender together with your written acceptance thereof, shall constitute a binding contract between us.
5. We have submitted the Tender Fees, EMD/exemption for the same as per the instructions.
6. We further agree that in the event of our withdrawing the tender before the receipt of the final decision or in the event of our failing to deposit the Performance Security in such form as contained in the GCC of tender or in

the event of our tender being accepted, fail to execute an agreement in the form aforesaid within 14 days or extended time thereafter from the date of receipt of letter of acceptance, we may be disqualified and debarred for a period of two (2) years from participating for tenders at New Mangalore Port Authority duly informing the MSME authorities if applicable.

7. We agree that the payment shall be made direct to us by the Port Authority in Rupees.

8. We understand that you are not bound to accept the lowest or any tender you may receive.

Dated this _____ Day of _____ in the capacity of _____ duly authorized to sign the Tender for and on behalf of

(IN BLOCK CAPITALS)

Signature:

Witness

Address:

FORM OF AGREEMENT

THIS AGREEMENT made at Mangalore this ____ day of _____ BETWEEN M/s. _____ (hereinafter called "the Contractor") which expression shall unless excluded by or repugnant to the context or meaning thereof be deemed to include his heirs, executors, administrators successors and permitted assigns) of the one part and "The Board of New Mangalore Port Authority, a body constituted under Major Port Authorities Act 2021" having its Office at Panambur, Mangalore (herein after called "The Board") which expression shall unless excluded by or repugnant to the context or meaning hereof, be deemed to include their successors and assigns) of other part, WHEREAS the Board have accepted a tender by the Contractor for **"Providing illumination for the road near Godown No. 31 / PPP Hospital"** vide work order No.....dated.....

NOW THIS AGREEMENT WITNESSESTH AS FOLLOWS:

1. In this agreement words and expressions shall have the same meaning as are respectively assigned to them in the conditions of Contract hereinafter referred to.
2. The following documents annexed herein shall be deemed to form and be read and construed as part of this Agreement, viz –
 - a) The said tender
 - b) The acceptance of tender
 - c) The conditions of Contract
 - d) The scope of work/specifications.
 - e) The Price schedule and all other Annexures
 - f) The Contractor's all correspondence, by which the Contract is added, amended, varied or modified in any way by mutual consent.
3. In consideration of the payments to be made to the Contractor as hereinafter mentioned the Contractor HEREBY COVENANT with the Board for **"Providing illumination for the road near Godown No. 31 / PPP Hospital"** in conformity in all respects with the provision of the Contract.

4. The Board HEREBY COVENANT to pay to the Contractor in consideration of the work of **“Providing illumination for the road near Godown No. 31 / PPP Hospital”**, the Contract Price or and such other sum as may be payable at the time and in the manner prescribed by the Contract.
5. IN WITNESS WHEREOF the parties hereunto have set their hands and seals, the day and year first above written. This Agreement is assigned as CMEA-/202 -2 dated...../..../2024 and contains with.....pages in all.

Signed, sealed and delivered

by _____ for and on behalf of

(Contractor)

COMPANY SEAL

CHIEF MECHANICAL ENGINEER

For and On behalf of the NMPA

(Board)

- Witness
- 1.
 - 2.

FORMAT OF PERFORMANCE SECURITY DEPOSIT BANK GUARANTEE

1. In consideration of “The Board of New Mangalore Port Authority, a body constituted under Major Port Authorities Act 2021”(hereinafter called “The Board”) which expression shall unless excluded by or repugnant to the context or meaning thereof be deemed to include its successors and assigns has awarded the Contract for **“Providing illumination for the road near Godown No. 31 / PPP Hospital”** vide Work Order No._____(hereinafter called ‘the Contract’) to M/s. “Name of the Contractor” (hereinafter called the ‘Contractor’) which expression shall unless excluded by or repugnant to the context or meaning thereof be deemed to include his heirs, executives, administrators, successors and permitted assigns under the terms and conditions of the Contract, made between the Contractors and the Board, the Contractor is bound to submit a performance Guarantee of Rs.----- /-(Rupees-----) to Board, we the Corporation Bank, full address of the bank to be mentioned(hereinafter referred to as ‘the Bank’) at the request of the Contractors do hereby undertake to pay to the Board an amount not exceeding Rs._____/-(Rupees_____) against any loss or damage caused to or suffered or which would be caused to or suffered by the Board by reason of any breach by the Contractors of any of the terms and conditions of the said Contract.

2. We, _____ (Name of the Bank), do hereby undertake to pay Rs._____/-(Rupees_____) as the amounts due and payable under this guarantee without any demur, merely on a demand from the Board stating that the amount claimed is due by way of loss or damage caused to or which would be caused to or suffered by the Board by reason of the Contractor’s failure to perform the said Contract. Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Bank under this Guarantee. However, our liability under this Guarantee shall be restricted to an amount not exceeding Rs._____/-(Rupees _____).

3. We, _____(Name of the Bank), undertake to pay to the Board any money so demanded notwithstanding any dispute or disputes raised by the Contractor in any suit or proceeding before any court or Tribunal relating thereto, our liability under this present being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment there under and the Contractor shall have no claim against us for making such payment.
4. We, _____(Name of the Bank), further agree with the Board that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said Contract and it shall continue to be enforceable till all the dues of the Board under or by virtue of the said Contract have been fully paid and its claims satisfied or discharged or till the Chief Mechanical Engineer of the said Board certified that the terms and conditions of the said Contract have been fully and properly carried out by the said Contractors and accordingly discharge this guarantee. Unless the demand or claim under this guarantee is made on us in writing on or before _____, we shall be discharged from all liabilities under this guarantee thereafter. This Guarantee will remain in force from the date hereof, i.e. till _____ and unless a demand or suit or action to enforce any claim under the guarantee is made within three months from the date of expiry of this guarantee, i.e. on or before _____,all your rights under this guarantee shall be forfeited and we shall be relieved and discharged from all liabilities under this guarantee thereafter PROVIDED, that the Bank shall at the request of the Board but at the cost of the Contractors, renew or extend this guarantee for such further period or periods as the Board may require from time to time.
5. We, _____(Name of the Bank), further agree with the Board that the Board shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Contract or to extend the time of performance by the said Contractors from time to time to postpone from any time or from time to time any of the powers exercisable by the Board against the said Contractors and to forebear or enforce any of the terms and conditions relating to the said Contract and we shall not be relieved from our liability by reason of any such variation or extension being granted to the Contractors or for any forbearance, act or omission on the part of the Board or any indulgence shown by the Board to the Contractors or by any such matter or thing whatsoever which under the law relating to sureties would but for this provision, have effect of so relieving us.

6. This Guarantee will remain valid for the entire period as agreed, even though there happens to be change in the constitution of the bank or that of the Contractor.
7. We, _____(Name of the Bank), lastly undertake not to revoke this guarantee during its currency except with the previous consent of the Board in writing.
8. Our liability under this Guarantee shall not exceed Rs._____/-(Rupees_____).
9. This Guarantee shall valid up to _____.
10. We, are liable to pay the guaranteed amount or any part thereof under this guarantee only & only if you serve us a written claim or demand on or before - ---/-----/202 .
11. The Bank Guarantee is en-cashable at our _____ branch at Mangaluru, Karnataka

Dated ----- day of -----2024

For

(Authorised Signatory/s)

(Name & Code No.)

(For and on behalf of Bank.)

Format for Declaration

(To be executed on bidder's letter head)

To _____

“Providing illumination for the road near Godown No. 31 / PPP Hospital”

Ref: _____

The undersigned, having studied the pre-qualification submission for the abovementioned project, hereby states:

- (a) The information furnished in our bid is true and accurate to the best of my knowledge.
- (b) That in case of being pre-qualified, we acknowledge that the Employer may invite us to participate in due time for the opening of Price cover of the tender on the basis of provisions made in the tender documents to follow.
- (c) When the call for tenders is issued, if the legal, technical or financial conditions, or the contractual capacity of the firm or joint venture changes, we commit ourselves to inform you and acknowledge your sole right to review the pre-qualification made.
- (d) We enclose all the required pre-qualification data format and all other documents and supplementary information required for the pre-qualification evaluation.
- (e) We state that no changes have been made by us in the downloaded tender documents and also understand that in the event of any discrepancies observed, the printed tender document No. _____ is full and final for all legal/contractual obligations (delete if not required).
- (f) No conditions are incorporated in the Financial Bid. In case any conditions are specified in the Financial Bid, the Tender will be rejected summarily without making any further reference to the Bidder.
- (g) We also state that we have not made any payment or illegal gratification to any person/authority connected with the bid process so as to influence the bid process and have not committed any offence under the PC Act in connection with the bid.
- (h) We also undertake that, currently we don't have any litigation.

Date: _____

Place: _____

Name of the Applicant : _____

Represented by (Name & capacity) _____

(To be executed on Non-Judicial Stamp Paper of Rs.100/-)

FORMAT OF POWER OF ATTORNEY (in original)

In favour of signatory/s to the Tender, duly authenticated by Notary Public.

POWER OF ATTORNEY IN FAVOUR OF ----- (Name, Designation, Company name)

TO ALL TO WHOM THESE PRESENTS shall come, I, (Name & address of the authorized person to sub-delegate/delegate powers, delegated on him by the Board of Directors) do hereby sub-delegate/delegate, in terms of the powers delegated to me by the Board of Directors, -----(name of the Co.) to Shri --- ----- (name, designation & address of the Attorney) the following:

NOW KNOW YE AND THOSE PRESENTS that I, (Name & address of the authorized person to sub-delegate/delegate powers, delegated on him by the Board of Directors), do hereby authorize and empower Shri ----- (name, designation & address of the Attorney) to do severally amongst others, for the purpose of carrying on our business, the following:

- a) To represent lawfully the (name of the Co.) for obtaining bid/tender documents, prepare, sign, execute and submit tenders for execution of **“Providing illumination for the road near Godown No. 31 / PPP Hospital”** Or any other works incidental to such works
- b) To discuss the technical and financial matters, negotiate and accept prices and take decisions regarding terms and conditions and sign agreements and contracts and also to bind the (name of the Co.) to the arbitration clause included in the contract.
- c) For all or any of the purposes here of to sign and deliver or otherwise execute such deed or deeds, transfer or transfers, endorsement or endorsements and to perform such other acts, matters, things as the Attorney shall consider requisite or advisable as full and effectively as the Company could do, if present and acting there.

I, (Name & address of the authorized person to sub-delegate/delegate

powers, delegated on him by the Board of Directors) in terms of the powers delegated to me by the Board of Directors of (name of the Co.), do hereby agree that all acts, deeds and things done by the said Attorney by virtue of this power of attorney, shall be construed as acts, deeds and things done by the Company.

I, (Name & address of the authorized person to sub-delegate/delegate powers, delegated on him by the Board of Directors), further undertake to ratify and confirm whatever our said attorney shall do or cause to be done for the Company, the said Company, in the premises, by virtue of the powers hereby given.

WHEREAS, this sub-delegation is signed and delivered to Shri ----- (name & designation of the Attorney), on this _____ day of _____, 20____ (Two thousand _____).

WHEREAS, even though this sub-delegation is signed on this _____ day of _____ 20____ (Two thousand _____), will have effect from the date he signs and receives this delegation.

IN WITNESS WHEREOF, I, (Name & address of the authorized person to sub-delegate/delegate powers, delegated on him by the Board of Directors) has, this _____ day of _____ 20____ (Two thousand _____) set my hands and subscribed my signature unto this instrument.

SIGNED AND DELIVERED ON

_____ BY

(Name of authorized person to delegate powers)

WITNESS:

SIGNED AND RECEIVED ON

_____ BY

(Name & designation of Attorney)

Bank Information for E-Payment

1	Name and full address of the Bidder	
2	Credit Account No. (Should be full 14 digit)	
3	Account type (SB or CA or OD)	
4	Name of the Bank	
5	Branch (Full address with Telephone No.)	
6	MICR code (should be 9 digit)	
7	Telephone/Mobile/Fax/ e-mail of the Bidder	Telephone:
		Mobile:
		e-mail:
8	Xerox copy of a cheque should be enclosed	
9	PAN (Xerox copy of Permanent Account Number shall be enclosed)	

Signature and seal of the Bidder

DISPUTES REVIEW BOARD AGREEMENT

(To be executed on Rs.100/- non-judicial Stamp Paper)

THIS AGREEMENT, made and entered into this Day of _____20_____ Between ("the Employer/ Board") and ("the Contractor"), and the Disputes Review Board ("the DR Board") consisting of One/three DR Board Members, (Members from either party, i.e contractor and Employer/ Board)

- (1)
- (2)
- (3)

[Note Delete whatever is not applicable]

WITNESSETH, that
WHEREAS, the Employer/ Board and the Contractor have contracted for the execution of (P r o j e c t n a m e) (t h e "Contract") and WHEREAS, the contract provides for the establishment and operation of the DR Board NOW THEREFORE, the parties hereto agree as follows -

- 1. The parties agree to the establishment and operation of the DR Board in accordance with this DR Board Agreement.
- 2. Except for providing the services required hereunder, the DR Board Members should not give any advice to either party or to the Engineer or Engineer’s Representative concerning conduct of the Works.

The DR Board Members

- (a) shall have no financial interest in any party to the contract or the Engineer or Engineer’s Representative, or a financial interest in the contract, except for payment for services on the DR Board_
- (b) shall have had no previous employment by, or financial ties to, any party to the contract, or the Engineer or Engineer’s Representative, except for fee based consulting services on other projects, all of which must be disclosed prior to appointment to the DR Board.
- (c) shall have disclosed in writing to the parties prior to signature of this

Agreement any and all recent or close professional or personal or personal relationships with any director, officer, or employee of any party to the contract, or the Engineer or Engineer's Representative, and any and all prior involvement in the project to which the contract relates;

- (d) shall not, while a DR Board Member, be employed whether as a consultant or otherwise by either party to the contract, or the Engineer or Engineer's Representative, except as a DR Board Member.
- (e) shall not, while a DR Board Member, engage in discussion or make any agreement with any party to the contract, or with the Engineer or Engineer's Representative, regarding employment whether as a consultant or otherwise either after the contract is completed or after services as a DR Board Member is completed;
- (f) shall be and remain impartial and independent of the parties and shall disclose in writing to the Employer/ Board, the Contractor, the Engineer or Engineer's Representative, and one another any fact or circumstances which might be such to cause either the Port or the Contractor to question the continued existence of the impartiality and independence required of DR Board Members.

3 Except for its participation in the DR Board's activities as provided in the contract and in this Agreement none of the Employer/ Board, the Contractor, the Engineer or Engineer's Representative, and one a nother any fact or circumstances which might be such to cause either the Employer/ Board or the Contractor to question the continued existence of the impartiality and independence required of DR Board Members.

4 The Contractor shall

- a) furnish to each DR Board Members one copy of all documents which the DR Board may request including contract documents, progress reports, variation orders, and other documents, pertinent to the performance of the Contract.
- b) in co-operation with the Employer/ Board, co-ordinate the Site visits of the DR Board, including conference facilities and secretarial and copying services.

5. The DR Board shall serve throughout the operation of the contract. It shall begin operation following execution of this Agreement, and shall terminate its activities -after issuance of the taking over Certificate and the DR Board's

issuance of its Recommendations on all disputes referred to it.

6. DR Board Member, shall not assign or subcontract any of their work under this Agreement
7. The DR Board Members are independent and not employees or agents of either the Employer/ Board or the Contractor.
8. The DR Board Members are absolved of any personal or professional liability arising from the activities and the Recommendations of the DR Board.
9. Fees and expenses of the DR Board Member[s] shall be agreed to and shared equally by the Employer/ Board and the Contractor. If the DR Board requires special services, such as accounting, data research, and the like, both parties must agree and the costs shall be shared by them as mutually agreed.
10. DR Board Site visits:
 - a) The DR Board shall visit the Site and meet with representatives of the Employer/ Board and the Contractor and the Engineer or Engineer's Representative at regular intervals, at times of critical construction events, and at the written request of either party. The timing of Site visit failing agreement shall be fixed by the DR Board.
 - b) Site meetings shall consist of an informal discussion of the status of the construction of the works followed by an inspection of the works, both attended by personnel from the Employer/ Board, the Contractor and the Engineer or Engineer's Representative.
 - c) If requested by either party or the DR Board, the Employer/ Board will prepare minutes of the meetings and circulate them for comments of the parties and the Engineer or Engineer's Representative.
11. Procedure for disputes referred to the DR Board :
 - a) If either party objects to any action or inaction of the other party or the Engineer or Engineer's Representative, the objecting party may file a written notice of Dispute to the other party with a copy to the Engineer or Engineer's Representative stating that it is given pursuant to Clause [number] and stating clearly and in detail the basis of the dispute.
 - b) The party receiving the notice of Dispute will consider it and respond in writing within 7 days after receipt.
 - c) This response shall be final and conclusive on the subject, unless a

written

appeal to the response is filed with the responding party within 7 days of receiving the response. Both parties are encouraged to pursue the matter further to attempt to settle the dispute. When it appears that the dispute can not be resolved without the assistance of the DR Board either party may refer the dispute to the DR Board by written Request for Recommendation to the Board, the other party and the Engineer or Engineer's Representative stating that it is made pursuant to (*insert relevant clause no.*).

- d) The Request for recommendation shall state clearly and in full detail the specific issues of the dispute to be considered by the DR Board.
- e) When a dispute is referred to the DR Board, and the DR Board is satisfied that the dispute requires the DR Board's assistance, the DR Board shall decide when to conduct a hearing on the dispute. The DR Board may request that written documentation and arguments from both parties be submitted to each DR Board Members before the hearing begins. The parties shall submit insofar as possible agreed statements of the relevant facts
- f) During the hearing, the Contractor, the Employer/ Board, and the Engineer or Engineer's Representative shall each have ample opportunity to be heard and to offer evidence. The DR Board's Recommendations for resolution of the dispute will be given in writing, to the Employer/ Board, the Contractor and the Engineer or Engineer's Representative as soon as possible, and in any event not more than 28 days after the DR Board's final hearing on the dispute.

12 Conduct of Hearings:

- a) normally hearing will be conducted at the Site, but any location that would be more convenient and still provide all required facilities and access to necessary documentation may be utilised by the DR Board. Private sessions of the DR Board may be held at any location convenient to the DR Board,
- b) The Employer/ Board, the Engineer or Engineer's Representative and the Contractor shall have representatives at all hearings.
- c) During the hearings, no DR Board Member shall express any opinion concerning the merit of any facet of the case.

- d) After the hearing is concluded, the DR Board shall meet privately to formulate its Recommendations. All DR Board deliberations shall be conducted in private, with all individual views kept strictly confidential. The DR Board's Recommendations, together with an explanation of its reasoning shall be submitted in writing to both parties and to the Engineer or Engineer's Representative. The Recommendations shall be based on the pertinent contract provisions, applicable laws and regulations, and the facts and circumstances involved in the dispute.

The DR Board shall make every effort to reach a unanimous Recommendation. If this proves impossible, the majority shall decide and the dissenting member any prepare a written minority report for submission to both parties.

[Note: Delete if it is one member DR Board]

13. If during the contract period, the Employer/Board and the Contractor are of the opinion that the Dispute Review Board is not performing its functions properly, the Employer/Board and the Contractor may together disband the Disputes Review Board. In such an event, the disputes shall referred to Arbitration straightway.

The Employer / Board and the Contractor shall jointly sign a notice specifying that the DR Board shall stand disbanded with effect from the date specified in the notice. The notice shall be posted by a registered letter with AD or delivery of the letter, even if he refuses to do so.

Annexure - 9

DETAILS OF ONGOING CONTRACTS AT NMPA BEYOND 31.01.2025

Sl no	Work Order Description	Work Order no. & date	Work Order Value	Department which has issued the Work order	Date of completion as per work order

Sign & Seal of the Contractor

Annexure-10

VERIFICATION OF LOCAL CONTENT

Tender no & Name of the work	Bidder shall enter, the % of Local Content
	(%)
Tender No. NMPA/Mech/EE(E)I/2024/0976-1, dtd 06.02.2025 “Providing illumination for the road near Godown No. 31 / PPP Hospital”	

Sign & Seal of the Contractor

UNDERTAKING ON INDEMNIFICATION

We _____ (Bidders Name) hereby agree and undertake to indemnify, keep indemnifies, depended and hold harmless the NMPA and its Officers against all losses, penalties, costs and expenses, duties of any kind whatsoever which may arise on account of breach un-authorized act, fraud deed or any other acts of ours or any of our personnel. We hereby further agree and undertake to indemnify and keep indemnifies against any order passed by any executive, quasi judicial or judicial authority wherein the NMPA is compelled to obey the order which arise due to breach of contract by us.

We _____(Bidders name) shall indemnify, protect and defend at our own cost, New Mangalore Port Authority and its agents & employees from & against any/all actions, claims, losses or damages arising out of;

- i. Any violation in course of execution of the contract of any legal provisions or any right of third parties.
- ii. Failure to exercise the skill and care required for satisfactory execution of the contract.
- iii. Shall indemnify NMPA against all claims for compensation by or on behalf of any workman employed by us in connection with the contract, for injury or death by accident under the Workman Compensation Act (Act VIII of 1923) as amended from time to time.

We _____(Bidders name) shall be responsible for all commissions and omissions on part of manpower engaged for the purpose. NMPA shall not be responsible in any manner whatsoever, in matters of injury/death/health etc. of our employees performing duties under the contract.

We _____(Bidders name) hereby undertake that ,

The workforce deployed under this contract will be provided with all the necessary safety gears and equipment for the job.

- a. Bidder/deployed staffs will follow all the required safety procedures while executing the job.

Sign and Seal of the Bidder/ Bidders Authorized representative

INDEMNITY BOND

(To be furnished in Stamp paper not less than Rs.100 e-Stamp paper)

This deed of indemnity is executed by herein after referred to as 'Indemnifier' which expression shall unless repugnant to the context or meaning thereof, include its successors, Administrator, representatives and assignees in favour of New Mangalore Port Authority, Panambur, Mangalore 575010, herein after referred to as 'Indemnified' which expression shall unless repugnant to the context or meaning thereof include its representatives and assignees witnesses as to.

Whereas the indemnified herein as awarded to the indemnifier herein a Tender/Contract or for supply of / Construction of on terms and conditions set out interalia in the work order No..... valued at Rs.....

AND Whereas, the clauses No..... of the above mentioned work order provides for indemnifying the indemnified by the indemnifier for any accident, damage or compensation payable to any workmen or other person in the employment of the contractor or any sub contractor during the period of tender/contract.

AND Whereas, the Indemnifier hereby irrevocably agrees to indemnify the indemnified against all damages or compensation payable at law in respect of or in consequence of any accident or injury to any workmen or other person in the employment of the contractor or sub-contractor against all claims, demands, proceedings, costs, charges and expenses whatsoever in respect thereof or in relation thereto and the indemnified shall be at liberty to deduct or adjust from the bills payable to the indemnifier by the indemnified for an amount that the indemnified may be called upon to pay towards claims, demands, proceedings, costs, charges and expenses whatsoever in respect of or in relation to any accident or injury referred to above without any reference to the indemnifier.

The Indemnifier shall comply with all the Central State and Muncipal Laws and Rules and shall be solely responsible for complying with the provisions of the Contract Labour (Regulations & Abolition) Act, 1970 & the contract labour (Regulation & Abolition) Karnataka Rules 1974 and rules there under and the enactments that may be applicable including ESI Act, the payment of wages act, Provident Fund Act, the Minimum Wages Act, the Factory's Act, the Workmen Compensation Act or any other applicable legislation and the Muncipal by-laws or other statutory Rules and Regulations whatsoever in force if these are applicable. Any obligations finding or otherwise missed under any statutory enactments rules & regulations there under shall be the responsibility of the

Indemnifier and the Indemnified will have no responsibility for the same. The Indemnifier shall obtain Workmen's Compensation Policy for his workers, who are not covered under ESI and submit the same to the ESIC immediately after commencement of the work.

The Indemnifier is liable to pay all Statutory Compensation to the Labourers / persons engaged by him for the satisfactory execution of the works. If any claim is made against Indemnified arising out of this work, the Port shall have the right to deduct the same from the bill amount payable to the Indemnifier after verification of the validity and if admissible as per rules.

The Indemnifier shall ensure the use of PPE such as helmets, safety shoes, nose masks, hand gloves, safety harness or any other equipment as required depending on nature of work by his staff at site.

In addition to complying of the above, the Indemnifier hereby undertakes to indemnify the indemnified against any unforeseen incidents / accidents, which may lead to fatality including death, permanent/ partial disablement, injury, financial loss, legal issues or any other etc of the labourers / workmen's/ staffs of the contractor / sub-contractor for which the indemnified and its officers / representation are in no way responsible.

For.....

INDEMINIFIER

(Signature with Name and Designation)

Company Seal

Station:

Date:

Witness:

1.....

Signature with Name, Designation & Address

2.....

Signature with Name, Designation & Address

BILL OF QUANTITIES

TENDER NO: NMPA/Mech/EE(E)I/2024/0976-1

Dated: 06/02/2025

**Name of Work: "Providing illumination for the road near Godown No. 31/
PPP Hospital"**

Sl. No.	Item Description	Qty.	Unit	Rate (Rs)	Amount (Rs)
01	Supply of 20M high mast shaft in two sections suitable for 39 m/sec wind speed, with head frame, winch mounting bracket, luminaries carriage suitable to install 10 nos. luminaries in symmetrical arrangement. As per Technical Specifications	1	No.		
02	Supply of raising, lowering system comprising double drum winch, 6mm diameter SS wire rope, trailing cable, connector, integral power tool motor, manual handle, junction box, lightening finial. As per Technical Specifications	1	No.		
03	Supply of foundation bolts manufactured from special steel along with nuts, washers, anchor plate and common template. As per Technical Specifications	1	Set		
04	Supply, Installation, testing & commissioning of 500 W LED Flood light fittings complete with driver and necessary accessories as required to maintain average 25 Lux for keeping minimum uniformity. Bidder to submit illumination design with location of the mast. Housing material of the flood light should be Matt Grey powder coated pressure Die-cast aluminum housing, with heat resistant tempered glass cover. System wattage of the luminaire should be within 500W and system lumen output should not be less than 120	10	Nos.		

	lm/W. And total Luminous flux shall be 60000 lm (+/- 10%). The fixture should be available with choice of beam angles of NB A3 -25°. Fixture should be suitable for a input voltage range of 120 V to 277 V AC with input power supply of 230V AC ± 10 %. Lifetime should be at least 50,000 burning hours. Ingress protection class of IP 66 and impact resistance of IK 08. Bidder to submit LM 79-80 report of the luminaire from NABL / Govt. approved test house along with BIS certificate as required. As per Technical Specifications.				
05	Supply of low intensity LED type single dome aviation obstruction light. As per Technical Specifications.	1	No.		
06	Construction of shallow foundation with M25 grade concrete for the high mast considering the safe soil bearing capacity at site as 10 T/sqmtr at 2 metre depth with all materials and labour. As per Technical Specifications.	1	No.		
07	Erection of the high mast with the help of suitable tools and plants, wiring of luminaires with all wiring materials like PVC insulated PVC sheathed flexible cable of suitable copper conductor cores of 1.5 sq. mm, lugs, MCB and all labour as a complete.	1	No.		

08	<p>Supply of outdoor High Mast control panel made of SS 304 Grade Stainless steel Enclosure of size 600(W) X760(H) X210(D) mm with rain canopy, single door type with cam lock door sealing gasket and gland plate with required openings etc. Material 2.00mm thick and mounting plate 2.5mm thick comprising the following components with control wiring 10 Sq.mm copper wire for lighting circuit and 2.5 Sq.mm copper wire for motor circuit and termination with suitable lugs. work including supply & fixing of the components complete etc. as per technical specifications.</p> <ol style="list-style-type: none"> 1. 1 no 63A, 4P, 25KA MCCB 2. 3 nos 32A, SP MCB for High Mast control 3. 3 nos 32A, SP, MCB for Motor Control 4. 4 nos, 100A, CBT connectors-4nos 5. 16Amps Connectors – 4 nos. 6. 16Amps Connectors – 4 nos. 7. 1 no MNX 45, 3P, contactor with add on block. 8. 1 no 24Hrs timer 9. 1 no Auto manual selector switch to by-pass timer 10. forward and reverse Contactor with push button control to raise/lower the lantern carriage for fixed 3 phase, 415V winch Electric Motor of suitable rating as per the recommendations of manufacturer. <p>As per technical specifications.</p>	1	No.		
09	<p>Design & construction of RCC barricade wall around the high mast by using M 20 concrete with 10 mm vertical rod at a gap of 200 mm double layer and 3 rows of 8 mm horizontal rod by keeping 2000 mm inner radius from centre of high mast foundation as per the specifications.</p> <p>As per Technical Specifications</p>	1	No.		

10	<p>Providing RCC/Stone masonry foundation for the High Mast control Panel and the dimension of the foundation is 800(W) x 1000(H) x 400(D) mm and gap between the pillars is 350 mm for cable connection to the control panel. The foundation starts 300mm below the ground after making 100mm stone soling and height of the foundation 500mm above the high Mast foundation level and curing etc. and the panel should be stand on the four Stainless steel bolts (12mm x 6")and each bolt with four nuts & washers at 50mm height from the foundation and complete.</p> <p>As per Technical Specifications</p>	1	No.		
11	<p>Providing GI pipe earthing for High Mast & feeder pillars using 40 mm dia 2.9 mm thick, 2.5 meter long GI pipe with GI funnel with mesh and suitable size reducer fixed on the top of the earth electrode. The funnel should be enclosed in a CC chamber of 400 x 400 x 400 mm with a cast iron cover. The electrode shall have staggered holes of 12-mm dia and the electrode should be covered 150 mm around with alternate layers of salt and charcoal from the bottom of the pipe to the bottom of the CC chamber the connection from the electrode is to be established through GI Flats. (25x3mm for lighting and panel & 50 x 6mm for lightning arrestor) using GI bolts and nuts. work includes supply & fixing of required GI flats for each earthing connection.</p>	2	Nos.		
12	<p>Installation and commissioning of the stainless steel high mast control panel by terminating the required cables such as Incomer, lighting and motor. Work also including supply and fixing of required materials such as glands lugs etc. complete.</p>	1	No.		

13	<p>Design, Fabrication, supplying and erection of 9 Mtrs long hot dip Galvanized, Octagonal Street light poles with BSEN 10025 GRADE S355JO steel plate for shaft, IS 2062 for base plate with door opening arrangements , including suitable boards, Bakelite sheet and MCB's as per IS specifications suitable to withstand the wind speed of 47 m/s for 9 Mtr Pole in single section and single joint welded as per IS 9595/IS10178AWS having dimensions bottom 155mm dia , top 70mm dia with 3mm thick suitable base plate 260X260X16mm, PCD 250 and foundation bolts M24X750mm long 4 nos " J" type along with template and the Pole shall be hot dip galvanized in single dipping with not less than 65micron as per ASTM-A123 and 153 etc. (excluding foundation) as per drawing appended.</p> <p>a) 9m-Top 70mm and Bottom 155mm dia</p>	15	Nos.		
14	<p>Supplying and fixing of Hot dip Galvanized M.S. Bracket suitable for outdoor Luminaries and mounted on Octagonal pole using necessary bolts, nuts etc., complete.</p> <p>a) Single Arm Bracket with 1500mm Standard 40/50mm dia</p>	15	Nos.		
15	<p>Providing foundation for 9 mtrs Octagonal pole including Earth Excavation and making of RCC foundation using M 20 concrete, steel reinforcement, shuttering complete as per pole suppliers approved foundation drawing or depending upon site condition. (All supply materials included in this item).</p>	15	Nos.		
16	<p>Supply and drawing Flexible Multicore cable manufactured with electrolytic grade flexible copper with low conductor confirming to IS:8130-1984 and (Virgin) PVC</p>	200	Mtrs		

	insulation sheathed suitable for working voltage up to 1100 volts as per IS-694:1990. a) 3C X 2.5 sq.mm				
17	Supplying of 1.1KV XLPE insulated, PVC extruded inner sheath Armoured LT UG Cable as per IS-1554(Part-I) or IS-7098(Part-I) Armouring strip thickness and resistivity as per IS-3975. a) 3.5C X 25 sqmm	550	Mtrs		
18	Supplying of 1.1KV XLPE insulated, PVC extruded inner sheath Armoured LT UG Cable as per IS-1554(Part-I) or IS-7098(Part-I) Armouring strip thickness and resistivity as per IS-3975. a) 3.5C x 50 sq.mm	175	Mtrs		
19	Labour charges for laying of following size 1.1KV class XLPE UG cable/on wall with SS saddles with necessary screws /GI Pipe as required etc., as complete job. a) 3.5 Core x 25 sq.mm	550	Mtrs		
20	Labour charges for laying of 1.1 KV class XLPE LT UG Cable in existing trench / GI pipe / Stoneware pipe / on pole/on concrete wall as required. a) 3.5C X 50 sq.mm	175	Mtrs		
21	Supplying and making end termination with glands, lugs of LT cable. a) 3.5C x 25 Sq.mm	30	Sets		
22	Supplying and making end termination with glands, lugs of LT cable. a) 3.5C x 50 Sq.mm	2	Sets		
23	Earth work excavation for cable trench of 0.5 to 0.75 Mtr. Width and depth up to 1 Mtr including trial pit, depositing on bank up to a lead of 50 Mtr. Supplying and displaying necessary danger boards and lighting, using sight rails and sign boards at every 100 Mtr wherever necessary as directed. a) Hard Soil	275	CMT		

24	Refilling the cable trenches with selected available earth from trench excavation including watering, consolidation in layers of 15 cm. Thickness including depositing of the surplus earth with a lead of 200 Mtr.	275	CMT		
25	Supplying and laying Double walled corrugated DWC HDPE pipe as per IS 14930 part II with necessary connecting sockets, couplings, Tees, bends, End - caps of same materials in existing trench/duct/pole/on wall/on black stone wall with SS saddles/ on poles/structure drawing the cable with supply and fixing DWC pipe with Aluminium clamps and stainless steel screws as required for drawing the cable as complete job. a) 40mm OD/32mm ID.	600	Mtrs		
26	Supplying and laying Double walled corrugated DWC HDPE pipe as per IS 14930 part II with necessary connecting sockets, couplings, Tees, bends, End - caps of same materials in existing trench/duct/pole/on wall/on black stone wall with SS saddles/ on poles/structure drawing the cable with supply and fixing DWC pipe with Aluminium clamps and stainless steel screws as required for drawing the cable as complete job. a) 63mm OD/50mm ID	175	Mtrs		
27	Supply of LED streetlight luminaire with pressure are cast aluminium housing body for optimal thermal dissipation. Lamp compartment comprising of anti-glare clear diffuser with Injection moulded polycarbonate material, delivering superior light output rated life Burning Hrs. 5000hr @Lumen Maintenance of 70%,maximum light intensity should be between 60 degree to 70degree.CCT>5500k,IP66 optical and electrical compartment & impact resistance of complete	15	Nos.		

	<p>luminaire>1K08. Power factor>0.9 with mains, Surge Protection -Min 5KV along with Over voltage /Overload/Short circuit/miss-wiring protection. Compatible for pole mounting with outer dia of 40mm to 50mm. Universal Voltage driver to operate wide voltage range from 100V to 270V 50/60Hz application. Compliance to IS 10322/IEC 60598, LM 79& LM 80 Adherence with RoHS. UL approved MCPCB. Top access street light with single screw to ensure ease of maintenance at the sight site location minimized minimal tools. LED Light fixture with 150W System power consumption. LED Efficiency>130 lm/w, nominal CRI>75.Luminaire manufacture should have accredited by NABL/CPRI & any Government certified agency & Design & Development facility certified ISO 9001:2008.Housing with Supplier word mark/name shall be Engraved/Embossing on the die cast housing/Body part. Warranty of 2 years against any manufacturing defect.</p> <p>LED Streetlight 150W</p>				
28	Fixing and wiring of 150W LED street light fittings with suitable clamps brackets, lamps, bolts and nuts to 9 mtrs long poles.	15	Nos.		
29	Supply and fixing of Spiral earthing Electrode as per standard technical specifications as per ESCOM.	15	Nos.		
30	Supplying and fixing of street light timer box of size 300x600x170mm made of thermoplastic modular panel with lid, shock proof, IP 65 having internally embedded gasket on both lid and flap with hylum sheet, din rail with 10sqmm copper wire as complete and consisting of following components, a) 63A TPN MCB-1 No	1	Nos.		

	b) MNX 40A 4-pole Contactor-1 No c) 20A TPN MCB-2Nos d) 24 Hrs Time swtch-1 No. e) 40A Connectors-10 Nos.				
31	Supplying and laying reinforced cement concrete pipe NP3 for culverts including pointing ends, and fixing collars with cement mortar 1:2 including cost of materials, labour, curing HOM complete as per specifications. No. KSRB 1000/2300. a) 300mm dia.	20	Mtr		
32	Supply and Installation of Cable Route Marker made up of RCC block of size 100cm (H) X 50cm (W) X 6cm (D) indicating Embossed text as NMPA LT Cable with Yellow paint and Red colour letters are fixing with cement concrete.	5	Nos.		
	Total				
	Applicable GST @ 18%				
	Grand Total including GST				

Note:

- 1. Applicable GST shall be mentioned separately.**
- 2. L1 will be considered based on BOQ exclusive of GST.**

NMPA BANK DETAILS

Name of the Payee:

The FA & CAO, NMPA, Panambur, Mangaluru for remitting Tender fee through NEFT / RTGS.

1	Name of the bank	State Bank of India, Panambur, Mangaluru -575 010
2	Bank Account No.	10205649448
3	IFSC Code.	SBIN0002249
4	MICR Code.	575002011

CHECK LIST

TENDER NO: NMPA/Mech/EE(E)I/2024/0976-1

Dated: 06/02/2025

SCHEDULE FOR CHECKLIST OF DOCUMENTS TO BE UPLOADED ALONG WITH TECHNO-COMMERCIAL BID

DETAILS OF DOCUMENT TO BE SUBMITTED		YES	NO	
TECHNICAL BID	1	EMD & Tender fee or supporting document for exemption of EMD /Tender Fee as per clause 2.2.1 (n)		
	2	Supporting documentary evidence of work orders and satisfactory completion certificate issued by the client duly self-attested and TDS certificate of the supporting work.		
	3	Copies of Profit and Loss Account statements, balance sheet and Auditor's report for the last three years, endorsed by Chartered Accountant with attestation.		
	4	Certificates: a) Valid Electrical Contract License b) GST Registration Certificate. c) ESI, PF Registration Certificates & PAN card copy		
	5	Tender Document, sealed and signed by the bidder along with Pre-bid replies, Corrigendum/Addendums if any.		
	6	a) Annexure - 1 - Particulars of Bidder. b) Annexure - 2 - Tender Form c) Annexure - 5 - Format of Declaration d) Annexure - 6 - Power of Attorney in original by Post/courier e) Annexure - 7 - Bank information for E-payment f) Annexure - 8 - Dispute review Board agreement g) Annexure - 9 - Details of ongoing Contracts at NMPA h) Annexure - 10- Verification of Local Content i) Annexure - 11 - Undertaking on indemnification j) Annexure -12 - Indemnity Bond		
PRICE Bid	PART-III - Price Schedule (Online Mode Only)			